

**Room Name** | **Ultrasound**

**Room Number: ULTR**

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	14.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient with up to 1 support person; 1-2 staff
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> Available 24 Hours
<b>Acoustics</b>	Acoustic privacy is required
<b>Description / Special Requirements</b>	Room for diagnostic ultrasound procedures, located close to patient toilet and change rooms. The room will require access for patients on hospital beds. Acoustics: Acoustic privacy required Body Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	flush set plasterboard ceiling also acceptable
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9110	Door - 1400mm	Solid Core	Paint	1 1/2 leaf	1400mm clear opening
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	at 1000H, open under part
FF-18445	Rack - scanhead storage	3	1	
FF-2100	Chair - ergonomic, office	3	1	
FF-23400	Bracket - television, ceiling	1	1	
FF-23950	Trolley	3	1	under bench
FF-2600	Chair - visitor, office	3	2	optional
FF-3350	Clock - battery operated	3	1	
FF-3400	Coathook	1	1	
FF-4345	Cupboard - sliding doors, adj shelves	3	1	lockable, optional
FF-4470	Cupboard - wall mounted, lockable	1	1	over bench, adjustable shelves
FF-4472	Cupboard - wall mounted, lockable	1	1	over bench, adjustable shelves
FF-4700	Curtain track - privacy screen (90 deg)	1	1	to entry door
FF-5250	Curtain - privacy screen	3	1	to entry door

Room Name | **Ultrasound**

Room Number: **ULTR**

AusHFG code	Description	Group	Qty	Comments
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-7500	Examination couch	3	1	mobile
FF-8100	Footstool	3	1	
FF-44108	Underbench single door (970hx450wx570d)		1	under part bench, adjustable shelf
FF-5824	Waste bin - general	3	1	to basin

### Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-B (sim)
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-57800	IMG - Ultrasound scanning unit	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-54551	Television - ultrasound image display	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

### Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6110	Downlights: dimmable	optional

### Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9001	GPO: Double	1	4	
S-9015	GPO: Cleaner	1	1	
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	

Room Name | Ultrasound

Room Number: ULTR

AusHFG code	Description	Group	Qty	Comments
S-6200	Light switches	1	1	
S-6110	Downlights: dimmable	1	1	optional
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light