

Room Name | Waiting, 10m2

Room Number: WAIT-10

Last modified	01/03/2016
Briefed Area	10.00
Remarks	
Occupancy	Up to 6
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	
Description / Special Requirements	<i>An area for visitors, patients and families to wait in comfort prior to or during visits to a Unit. A range of occupants will need to be considered including adults and children, both able-bodied, people with disabilities and provide bariatric capacity in many instances. An external outlook is desirable. Waiting areas may be shared between Units; public amenities including baby change facilities should be located nearby. Acoustics: sound attenuation level - high. Size of space and FF&E quantity/type to be adapted to suit specific project briefing requirements as per AusHFG HPU's. Add 1.2m2 per additional person and allow 1.5m2 for wheelchair parking space as required.</i>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1130	Floor finish	Carpet	90/10 Wool/ Nylon	Carpet tiles	Default = carpet, cushioned vinyl or standard slip resistant vinyl also acceptable.
3000	Wall finish	Paint	Acrylic, washable		
2535	Wall protection			Corner guards to 900 AFFL	Align heights of corner guards with other corridor elements
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
7001	Windows				desirable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH	Default = feather edged vinyl; or floor vinyl covered skirting for vinyl floor.

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments	
FF-13120	Rack - magazine/ pamphlet		3	1	
FF-17360	Pinboard - fabric covered		1	1	Protective, high impact cover with tamper proof locking mechanism optional.
FF-22800	Table - low		3	1	Number to suit chair layout.
FF-23410	Bracket - television, wall mount		1	1	optional
FF-2700	Chair - waiting		3	5	Some with arms and bariatric capability. Space for wheelchair.
FF-5830	Dispenser - antiseptic hand rub		2	1	
FF-5828	External window dressing		3	1	Number to align with window configuration. Window dressing type to comply with Infection Control policy.

Fixtures, Equipment and associated Services

Room Name | Waiting, 10m2

Room Number: WAIT-10

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2795	Television	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9001	GPO: Double	1	1	
S-1090	TV: MATV	1	1	
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	