

**Room Name** | Toilet - Accessible

**Room Number:** WCAC

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	5.00
<b>Remarks</b>	
<b>Occupancy</b>	1
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is required.
<b>Description / Special Requirements</b>	A toilet and handbasin for use by disabled persons with or without assistance. The room shall comply with AS 1428. Baby change facilities may also be located in this room. The room may be used by patients or visitors. If the Accessible Toilet is located in a patient care area the patient/nurse call and emergency call points should be included. Acoustics: Sound attenuation level - High - Acoustic privacy. Additional design requirements:- The entrance is to be flush with the adjoining floor- The door is to be fitted with escape hardware

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default = Vinyl; tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable		
2708	Wall finish			Splashback to basin	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'; both sides
8040	Door protection	Composite	Prefinished PVC	To door frame	Optional. To be decided at project level.
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910mm clear opening, privacy latch, emergency release
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default = Vinyl coved; or tiles for tiled floor

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror	1	1	
FF-19100	Waste bin - sanitary	3	1	Optional, depends on Waste Management Policy.
FF-3400	Coathook	1	2	
FF-390	Baby change table	1	1	optional
FF-6154	Dispenser - paper/ hand towel	2	1	
FF-6156	Dispenser - soap	2	1	to handbasin
FF-6160	Dispenser - toilet paper	1	1	
FF-8400	Grab rail - WC	1	1	
FF-7524	Grab rail - WC, accessible use	1	1	behind toilet

Room Name | Toilet - Accessible

Room Number: WCAC

AusHFG code	Description	Group	Qty	Comments
FF-5824	Waste bin - general	3	1	

### Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-3050	Basin - handwash, accessible	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Tapware: mixer, fixture mounted.
FE-5604	Toilet suite - accessible	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	With backrest. Concealed cistern, optional.

### Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

### Services

AusHFG code	Description	Group	Qty	Comments
S-4033	Floor waste	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light