

**Room Name** | Toilet - Patient

**Room Number:** WCPT

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	4.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; 1 staff assisting as required
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is required.
<b>Description / Special Requirements</b>	The Patient Toilet is a room containing a toilet and a handbasin for patients to use independently or with nurse assistance. Maybe provided for multi-bed rooms, Ambulatory Care Units, Emergency Departments, etc. The door will be fitted with escape hardware to allow staff access in an emergency. Acoustics: sound attenuation level - high; Acoustic privacy required. Body protected electrical area.

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default = Vinyl; tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable		
2906	Wall finish			Splashback behind basin	
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910mm clear outward opening, privacy latch, emergency release
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Or tiles for tiled floor.

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror		1	
FF-19100	Waste bin - sanitary		3	Optional, depends on Waste Management Policy.
FF-3400	Coathook		1	2
FF-6154	Dispenser - paper/ hand towel		2	1
FF-6156	Dispenser - soap		2	1 to basin
FF-6160	Dispenser - toilet paper		1	1
FF-8400	Grab rail - WC		1	1 to side or wrap-around.
FF-8500	Grab rail - WC, hinged		1	1 optional, drop down rail
FF-8510	Grab Rail - SS		1	1 behind toilet
FF-5824	Waste bin - general		3	1

## Fixtures, Equipment and associated Services

Room Name | Toilet - Patient

Room Number: WCPT

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-55605	Toilet suite - patient	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-5603	Basin - ensuite	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5015	Ventilation	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-9040	Body protected	1	1	
S-4033	Floor waste	1	1	
S-5015	Ventilation	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-1983	General fluorescecent downlights	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light