



AUSTRALASIAN HFG STANDARD COMPONENTS

Room Layout Sheet


RLS Room Code: **CLUP-P**

Room Name:


CLEAN-UP ROOM (PATHOLOGY), 12m²




BIMID	DESCRIPTION
2000	FLOOR VINYL COVERED SKIRTING
3052	WALL FINISH - VINYL OR TILE
8010	DOOR PROTECTION
8040	DOOR PROTECTION - FRAME
FE-2800	BASIN - HANDWASH, TYPE B
FE-4045	TAPWARE - ELBOW MIXER 1
FE-47850	SINK, SS - DOUBLE IN BENCH
FE-49803	SINK - FLUSHING RIM
FE-58200	WASHER SANITISER - UTENSIL
FF-150	AIR FLOWMETER
FF-1010	BENCHTOP - STAINLESS STEEL WITH WET EDGE
FF-4410	CUPBOARD - UNDER BENCH DOUBLE - 800W X 870H X 600D
FF-4415	CUPBOARD - UNDER BENCH DOUBLE - 850W X 870H X 600D
FF-4468	CUPBOARD - UNDER BENCH - 400W X 870H X 600D
FF-5824	WASTE BIN, GENERAL
FF-6152	DISPENSER - DISPOSABLE GLOVES
FF-6154	DISPENSER - HAND TOWEL
FF-6156	DISPENSER - SOAP
FF-19810	SHELF - STAINLESS STEEL OVER BENCH
FF-24125	WASTE BIN - CLINICAL - 240L
FF-44711	CUPBOARD - OVERHEAD - SINGLE 400W X 600H X 350D
FF-44716	CUPBOARD - OVERHEAD DOUBLE 800W X 600H X 350D
S-1433	ISOLATOR
S-4000	HOTWATER OUTLET
S-4010	COLDWATER OUTLET
S-4033	FLOOR WASTE
S-4037	TUNDISH DRAIN
S-6055	SPECIAL TASK LIGHT, BUILT-IN
S-6200	LIGHT SWITCH - ROOM 2 WAY
S-7020	MEDICAL GAS OUTLET - MEDICAL AIR
S-9001	GENERAL POWER OUTLET - DOUBLE
S-9060	GENERAL POWER OUTLET - SPECIAL FOR EQUIPMENT




PLAN




ELEVATION 1



ELEVATION 2



ELEVATION 3



ELEVATION 4

MIN REQUIRED FOR ISOLATOR
MIN REQUIRED FOR TUNDISH
NOTE: ISOLATOR AND TUNDISH ARE REQUIRED FOR SOME MODELS ONLY
SERVICES AS REQUIRED IF UTENSIL WASHER IS INSTALLED.



REV	DESCRIPTION	DATE
2	This RLS has been redocumented	01.03.2016

FOR GUIDANCE

SCALE	RLS Room Code	Room Tag	REV
1 : 50 @ A3	CLUP-P	1.073	2