



AUSTRALASIAN HFG STANDARD COMPONENTS

Room Layout Sheet

RLS Room Code: **CONS**


Room Name:

CONSULT ROOM




BIMID	DESCRIPTION
2000	FLOOR VINYL COVERED SKIRTING
2526	VINYL FLOORING, NON-SLIP 2526
2527	WALL SPLASHBACK
2529	DOOR PROTECTION FRAME - 2529
2712	DOOR PROTECTION PLATE - 2712
FE-2800	BASIN - HANDWASH, TYPE B
FE-11400	COMPUTER - PC & MONITOR
FE-15900	DIAGNOSTIC SET - WALL MOUNTED
FE-20350	EXAMINATION COUCH - ELECTRIC
FE-31701	LIGHT - EXAMINATION - WALL MOUNT
FE-54520	TELEPHONE - HANDSET, HANDSFREE
FF-150	AIR FLOWMETER
FF-775	DISPENSER - BED ROLL
FF-1465	BRACKET - SUCTION BOTTLE
FF-1470	BRACKET - SHARPS
FF-2100	CHAIR - ERGONOMIC OFFICE
FF-2600	CHAIR - VISITOR OFFICE
FF-3400	COAT HOOK
FF-4600	CURTAIN TRACK - BED SCREEN
FF-5000	CURTAIN - BED SCREEN
FF-5824	WASTE BIN, GENERAL
FF-5830	DISPENSER - ANTISEPTIC HAND RUB
FF-5900	DESK
FF-6152	DISPENSER - DISPOSABLE GLOVES
FF-6153	DISPENSER - MOISTURISER
FF-6154	DISPENSER - HAND TOWEL
FF-6156	DISPENSER - SOAP
FF-6158	DISPENSER - SOAP ANTISEPTIC


BIMID	DESCRIPTION
FF-13700	MIRROR
FF-16250	OXYGEN FLOWMETER
FF-17360	PINBOARD - FABRIC COVERED
FF-19700	SHARPS BINS
FF-20000	ADJUSTABLE SHELVES
FF-21950	SUCTION ADAPTER
FF-22000	SUCTION BOTTLE
S-1006	VOICE DATA OUTLET - DOUBLE
S-1951	STAFF ASSIST CALL
S-6200	LIGHT SWITCH
S-7000	MEDICAL GAS OUTLET - OXYGEN
S-7020	MEDICAL GAS OUTLET - MEDICAL AIR
S-7040	MEDICAL GAS OUTLET - SUCTION
S-8000	PATIENT TO STAFF CALL
S-8005	PATIENT CALL HANDSET
S-8080	EMERGENCY CALL
S-9000	GENERAL POWER OUTLET - SINGLE
S-9001	GENERAL POWER OUTLET - SINGLE
S-9001	GENERAL POWER OUTLET - DOUBLE
S-9001	GENERAL POWER OUTLET - DOUBLE
S-9011	EMERGENCY POWER OUTLET - DOUBLE
S-9040	BODY PROTECTED
S-10005	DURESS ALARM
S-11000	MEDICAL SERVICES PANEL




PLAN




ELEVATION 5 (1 : 25 @ A3)




ELEVATION 1



ELEVATION 2



ELEVATION 3



ELEVATION 4



REV	DESCRIPTION	DATE
6	This RLS has been reviewed, redocumented and reissued	01.03.2016

FOR GUIDANCE

SCALE	RLS Room Code	Room Tag	REV
1 : 50 @ A3	CONS	1.078	6