

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 4120
Room Name	Store - Accountable Drugs	Room Code: STAD
Area	5.0 M2	
No of Rooms	1	
Subtotal of Area	5.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Also covers these Rooms		
Description/ Special Requirements	<p>The Store - Accountable Drugs is a strongroom for storage of accountable (Schedule 8) drugs and medications, located within the Pharmacy Unit. Refrigerated storage may also be required. The strongroom will require adequate ventilation and a gate door for security when the main door is open.</p> <p>Accountable drugs storage facilities are to comply with NSW Health Pharmaceuticals Services Branch Policy and the requirements noted in the NSW Police Service document - 'Minimising the Risks'.</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> - The strongroom should be independent of the rest of the building structure with no beams or columns passing through the ceiling, walls or floor - The ceiling, walls and floor should be constructed of concrete with a compressive strength of 70 m/p/a with either 1 cm thick tang bar or 1 cm thick reinforcing rods in three levels in a criss cross pattern. The ceiling, walls and floor should be a minimum thickness of 300mm. - The door should be torch and drill resistant, fitted with a combination lock facility incorporating duress features and an internal release mechanism in case persons are trapped within - A torch and drill resistant breather tube must be fitted, to comply with Fire Regulations - Security detection equipment should be incorporated into the alarm system, to detect any attack on the structure - A telephone should be installed for staff safety; the telephone should be concealed to restrict unauthorised tampering 	
Amendment	19.05.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
9030	Doors	Steel	Paint	Strongroom, security door		Equal to 'Chubb' Pacific 100
9032	Doors	Steel	Paint	Strongroom, grille gate door		inner door
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

Australasian Standard Project

Room Data Sheets

Department **Standard Components**
Room Name **Store - Accountable Drugs**

Room Tag: **4120**
Room Code: **STAD**

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench
19968	Shelving: pharmacy stock flow	Furniture/ Fitting	3	2	
21760	Storage unit: under bench	Furniture/ Fitting	1	1	drawer/ cupboard unit

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
44350	Refrigerator: drugs	3	1	yes	opt	—	—	—	—	—	—	under bench
54510	Telephone: handset, standard	3	1	—	yes	—	—	—	—	—	—	on bench, optional

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
5015	Ventilation	HVAC		ventilator port
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
9001	GPO: Double	Power	2	
9000	GPO: Single	Power	1	refrigerator
10005	Duress alarm	Security	1	to entry lock mechanism
10010	Reed switch / alarm	Security	1	to door and structure