

Department	Standard Components	Room Tag: 4230
Room Name	Store - Equipment, 14m2	Room Code: STEQ-14
Net Room Area Briefed	14.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	14.00 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2 intermittently	
Also covers these Rooms		
Description/ Special Requirements	The Equipment Store is used for the storage of medical equipment when not in use and recharging of electrical items. Space is required for parking of mobile equipment including IV poles, wheelchairs, lifting equipment, trolleys, cradles and commode chairs for the Unit. Hooks will be required for hanging equipment.	
Amendment	17.05.05, - First Draft 10.03.09, - 2009 AUSHFG Review; Fittings-equipment rail added, power added for recharging	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to 'Acrovyn'

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
7200	Hook: equipment	Metalwork	1	4	on mounting plate
13660	Metal shelving: 900x400x2100	Furniture/ Fitting	3	4	
7300	Rail: equipment	Metalwork	1	2	vertical for recharging pumps, optional
24400	Whiteboard	Furniture/ Fitting	1	1	900 x 900, optional

Fixtures, Equipment and associated Services (FE)

Services

ID	Description	Service Category	Qty	Selection / Remarks
----	-------------	------------------	-----	---------------------

Department | **Standard Components**
Room Name | **Store - Equipment, 14m2**

Room Tag: 4230
Room Code: STEQ-14

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	6	for equipment recharging