

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department	Standard Components	Room Tag: 4570
Room Name	Stress Testing	Room Code: STRT
Area	12.0 M2	
No of Rooms	1	
Subtotal of Area	12.0 M2	
Hours of Operation	Available 24 Hours	
Occupancy	1 patient; 1 - 2 staff	
Also covers these Rooms		
Description/ Special Requirements	Room for undertaking patient diagnostic stress testing procedures. The Stress Testing room should be located close to patient toilet and change rooms.	
	Acoustics: Acoustic privacy required	
	Body Protected electrical area	
Amendment	06.04.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin; tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1650	Chair: client	Furniture/ Fitting	3	1	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
3350	Clock: battery operated	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	1	
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department **Standard Components**
Room Name **Stress Testing**

Room Tag: **4570**
Room Code: **STRT**

ID	Description	Category	Group	Qty	Selection
7520	Exercise bicycle	Furniture/ Fitting	3	1	
22615	Table: computer	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	refer to BHWS-B (sim)
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	to computer table
56600	Treadmill: automatic	3	1	yes	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	2	call button on the handset
8000	Patient/ Staff call	Nurse Call	2	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	4	