

Department	Standard Components	Room Tag:	4590
Room Name	Toilet - Patient	Room Code:	WCPT
Net Room Area Briefed	4.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	4.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1 staff assisting as required		
Also covers these Rooms			
Description/ Special Requirements	<p>A toilet and handbasin for patient's use independently or with the assistance of one or two nurse. To be provided for multi-bed rooms or adjacent to communal patient areas. The door will be fitted with escape hardware to allow staff access in an emergency.</p> <p>Acoustics: Sound attenuation level - High. Acoustic privacy required.</p> <p>Body protected electrical area</p>		
Amendment	<p>08.12.03, - First Draft 09.02.05, - BOB User review, fittings modified 10.03.09, - 2009 AUSHFG Review; default finishes noted</p>		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn; both sides
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn; both sides
9001	Doors	Solid Core	Paint	Single leaf		910mm clear outward opening, privacy latch, emergency release
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Default = Vinyl; tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		Default = vinyl coved; or tiles for tiled floor
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
530	Basin vanity top	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	1 @ 1200 AFFL for wheelchair users
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin

Department **Standard Components**
 Room Name **Toilet - Patient**

Room Tag: **4590**
 Room Code: **WCPT**

ID	Description	Category	Group	Qty	Selection / Remarks
6160	Dispenser: toilet paper	Furniture/ Fitting	1	1	
8400	Grab rail: WC	Metalwork	1	2	1 behind toilet, 1 to side
8500	Grab rail: WC, hinged	Metalwork	1	1	optional, drop down rail
9200	Hook: for catheter bag	Metalwork	1	1	
10800	Hook: for IV flasks	Metalwork	1	1	
13700	Mirror	Metalwork	1	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
3120	Basin: vanity	1	1	___	___	yes	___	yes	yes	yes	___	
55605	Toilet suite: patient	1	1	___	___	yes	___	___	yes	yes	___	

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	