

# Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 4630</b>
<b>Room Name</b>	<b>Treatment Bay - Chemotherapy</b>	<b>Room Code: TRMT-CHE</b>
<b>Area</b>	9.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	9.0 M2	
<b>Hours of Operation</b>	0800 Hours to 1800 Hours, daily	
<b>Occupancy</b>	1 patient, 1support person, 1 staff assisting	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	The Treatment Bay - Chemotherapy is used for day treatment of patients undergoing cytotoxic treatments. A staff handwashing basin will be provided for each 4 bays (refer to Bay-Handwashing Tupe B for basin).	
<b>Amendment</b>	Body Protected electrical area 14.03.05, - First Draft 21.03.05, - BOB user review, gr 3 fittings modified	

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable
7001	Windows					Desirable

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	1 between 2 bays
1250	Blind: Venetian	Metalwork	3	1	to external windows
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	1 between 2 bays
23400	Bracket: television, ceiling	Metalwork	1	1	to each bay
2200	Chair: recliner	Furniture/ Fitting	3	1	or patient bed
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	1 between 2 bays
19800	Shelf: laminate	Furniture/ Fitting	1	1	for equipment
21950	Suction adapter	Furniture/ Fitting	3	1	1 between 2 bays
22000	Suction bottle	Furniture/ Fitting	3	1	1 between 2 bays
16200	Table: overbed	Furniture/ Fitting	3	1	

# Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department **Standard Components**  
 Room Name **Treatment Bay - Chemotherapy**

Room Tag: **4630**  
 Room Code: **TRMT-CHE**

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
31750	Light: examination, mobile	3	1	yes	___	___	___	___	___	___	___	
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	optional
54550	Television: 34 cm	3	1	yes	___	___	___	___	___	___	___	

## Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	1	1 per bay
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6050	Special: reading	Lighting		
7020	Medical Air (MA)	Medical Gases	1	1 per 2 bays
7000	Oxygen (O2)	Medical Gases	1	1 per 2 bays
7040	Suction	Medical Gases	1	1 per 2 bays
8080	Emergency call	Nurse Call	1	+ indicator button & light; shared for 4 bays
8005	Patient call handset	Nurse Call	1	call button on the handset, 1 per bay
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light, 1 per bay
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light, 1 per bay
9040	Body protected	Power		
9010	GPO: Emergency power, single	Power	1	to patient services panel
9000	GPO: Single	Power	3	to patient services panel
9060	GPO: Special: for equipment	Power	1	TV