

AX APPENDICES

AX.01 Schedule of Accommodation

A schedule of accommodation is shown below and lists generic spaces for this HPU. Quantities and sizes of spaces will need to be determined in response to the service needs of each Unit on a case by case basis.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

ENTRY / RECEPTION

AusHFG Room Code	Room / Space	SC / SC-D	Qty	m2	Remarks
RECLS-10	Reception / Clerical, 10m2	Yes	1	10	May be shared
WAIT-20	Waiting, 20m2	Yes	1	20	Adjust size to suit. May be shared.
WCPU-3	Toilet - Public, 3m2	Yes	2	3	1 male and 1 female
WCAC	Toilet - Accessible Room, 6m2	Yes	1	6	
OFF-S9	Office - Single, 9m2	Yes	1	9	Unit Manager
OFF-2P	Office - 2 Person Shared, 12m2	Yes	1	12	Workstations for general administration
STEPS-10	Store - Files, 10m2	Yes	1	8	If required
STPS-8	Store - Photocopy / Stationery, 8m2	Yes	1	8	Can be part of or included in central workstation area
PBTR-H-6	Patient Bay - Holding , 6m2	Yes	1	6	Bed or trolley for waiting patient. This space should be discrete with clinical staff overview if provided - e.g. need for patient privacy (optional)
BMEQ-4	Bay Mobile Equipment, 4m2	Yes	1	4	For mobile ECG machines (optional)
MEET-9	Meeting Room, 9m2	Yes		9	For interviews, consults. No. to be determined through service planning
CONS	Consult Room	Yes		12	Adjust number of rooms to service activity of optimum use.
	Discounted Circulation %			32%	

Australasian Health Facility Guidelines

DIAGNOSTIC AREAS

AushFG Room Code	Room / Space	SC / SC-D	Qty	m2	Remarks
	ECG Cubicle - 1 patient			9	Exam couch, chair, desk, ECG monitor, access to a hand basin. No. to be determined through service planning.
	ECG Room - 2 patients			18	Two curtained cubicles. Access to a shared hand basin. No. to be determined through service planning.
	Holter / Ambulatory BP Application			8	Number will depend on throughput unless standard consult rooms used
	Holter Analysis Room		1	12	Desks/benching to support 2-3 computers
	Pacemaker / ICD Follow-Up Clinical Room		1	14	Bed access; cardiac protection
	ECG Stress Testing Room		1	20	Includes resuscitation trolley
WCPT	Toilet - Patient, 4m2	Yes	1	4	Also for specimen collection if needed
	Shower / Toilet / Change - Access		1	8	Close access from the exercise labs
	Tilt Table Testing Rooms		1	16	Optional
BRES	Bay - Resuscitation	Yes	1	1.5	
	Echo Room - General		1	12	
	Echo Room - TTE		1	12	
	Echo Room - TOE		1	16	30m2 as per standard components in AushFG
ECHO	Echo Reporting Room	Yes	1	12	May be part of shared reporting area
CLUP-7	Clean-Up Room, 7m2	Yes	1	7	For initial cleaning of ECHO probes etc - prior to cleaning as per Part D: Infection Prevention and Control, Australasian Health Facility Guidelines (AHIA, 2015)
SSTN-10	Staff Station, 10m2	Yes	1	12	
OFF-S9	Office - Single Person, 9m2	Yes	1	9	Unit manager is based in unit (optional)
	Office - Workstation, 5.5m2		1	5.5	Number of workstations will depend on staff establishment.
STEQ-20	Store - Equipment, 20m2	Yes	1	20	
BLIN	Bay - Linen	Yes	1	2	
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	1	4	Mobile ECG Units
WCST	Toilet - Staff, 3m2	Yes	2	3	Unless shared facilities
SRM-15	Staff Room, 15m2	Yes	1	15	Includes beverage bay
	Discounted Circulation %			32%	

Australasian Health Facility Guidelines

CARDIAC CATHETER LABORATORY

AusHFG Room Code	Room / Space	SC / SC-D	Qty	m2	Remarks
RECLS-12	Reception / Clerical, 12m2	Yes	1	12	May be shared with adjoining unit. Spacing allowance for more than 1 staff member
OFF-2P	Office - 2 Person Shared, 12m2	Yes	1	12	Optional for administrative staff
STPS-8	Store - Photocopy / Stationery, 8m2	Yes	1	8	Space may be included as part of reception area
WAIT-10	Waiting, 10m2	Yes	1	12	8-10 places for chairs and wheel chair for relatives and for patient discharge
BBEV-OP	Bay Beverage, Open Plan, 4m2	Yes	1	4	Open beverage bay
INTF	Interview Room	Yes	1	10	1 or 2 rooms for post angiogram review, operator reviews, pre-admission interviews, consents etc.
CONS	Consult Room	Yes	1	12	1 or 2 rooms for examinations
CHPT	Change Cubicle - Patient, 2m2	Yes	2	2	As per standard components. May be included in area for pre-operative arrivals.
	Change Cubicle, Accessible, 4m2		1	8	Male and female, toilet and lockers
CLAB	Catheter Laboratory Procedure Room	Yes	1	55	Single Plane
CLAB	Catheter Laboratory Procedure Room	Yes	1	55	Bi - Plane
	EP Laboratory		1	55	Sized as per OT HPU
CLCRT	Catheter Lab Control / Reporting Room	Yes	1	14	Separate rooms are optimal. Shared rooms must take due consideration of audio and operational impacts.
	Control Room - EP Lab		1	15	Allow for 3 staff with up to 5m2 work spaces. Multiple staff will also stand and sit in this area. Located ideally at head or foot of bed not at the side for maximum patient and procedure visibility. Extensive rack space required for switches.
	Computer Equipment Room		2	10	For storage of large equipment not required in the lab e.g. 3D Mapping and RFA equipment, 'Radi' pressure wire monitors, Intra-vascular ultrasound (IVUS) machine.
SCRB-6	Scrub Up / Gowning, 6m2	Yes	1	6	May be combined to serve two rooms. Located external to the Catheter Laboratory.
	Bay - Lead Aprons		1	1	One per laboratory; may be shared between rooms. The storage method of lead aprons and other lead protection requirements should be reviewed in consideration of the volume required for these services and the safe access by staff to retrieve a lead gown and store them without folding the gowns.
	Store Sterile Stock / Set Up Room		1	20	
STEQ-14	Store - Equipment, 14m2	Yes	1	16	For storage of large equipment when not required in cardiac catheter procedure room
STGN-9	Store - General, 9m2	Yes	1	10	For storage of bulk items/boxes
CHST-10	Change - Staff (Male/Female), 10m2	Yes	2	10	Access to 1 male, 1 female. Comprises lockers, shower, toilet.
CLUP-7	Clean-Up Room, 7m2	Yes	1	7	Access for processing echo transducers. Refer Part D: Infection Prevention and Control, Australasian Health Facility Guidelines (AHIA, 2015)
	Viewing / Reporting Room		1	7	3 workstations
	Store - Films		1	4	Optional - use of digital storage systems / PACS
PBTR-H-9	Patient Bay Holding, 9m2	Yes	1	9	6 bays per laboratory plus 1 or 2 for TOE Rooms - to be reviewed if accessing shared recovery space.
BHWS-B	Bay - Handwashing, Type B	Yes	2	1	
	Staff Station / Clean Utility		1	10	
BPATH	Bay - Pathology	Yes	1	1	Benching for machine with an increase to 2m2 if including a pneumatic tube station
BBW	Bay - Blanket / Fluid Warmer	Yes	1	1	
BRES	Bay - Resuscitation	Yes	1	1.5	
BLIN	Bay - Linen	Yes	1	2	
DTUR-10	Dirty Utility Room, 10m2	Yes	1	10	
DISP-10	Disposal Room, 10m2	Yes	1	10	Large volume of packaging waste
OFF-S9	Office - Single Person, 9m2	Yes	1	9	Unit Manager
	Office - Workstation, 5.5m2		1	5.5	Optional: Cardiac technicians 5.5m2 per staff member
	Discounted Circulation %			35%	