

AX APPENDICES

AX.01 Schedule of Accommodation

A schedule of accommodation is shown below and lists generic spaces for this HPU.

Quantities and sizes of spaces will need to be determined in response to the service needs of each Unit on a case-by-case basis.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

ENTRY / RECEPTION/ WAITING

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Chairs	Qty x m2 4 Chairs	Qty x m2 6 Chairs	Remarks
AIRLE-10	Airlock - Entry, 10m2	Yes	1 x 10	1 x 10	1 x 10	Optional depending on location and scale of development.
RECL-10	Reception / Clerical	Yes	1 x 9	1 x 9	1 x 12	1 and 2 staff
STFS-10	Store - Files	Yes	1 x 6	1 x 8	1 x 10	
STPS-8	Store - Photocopier / Stationery, 8m2	Yes	Share	1 x 8	1 x 8	
WAIT-10	Waiting	Yes	1 x 10	1 x 16	1 x 24	Based on 3 people per dental chair
PLAP-10	Play Area - Paediatrics, 10m2	Yes	Incl. in Waiting	1 x 10	1 x 10	Optional
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	Share	1 x 2	1 x 2	1 -2 wheelchairs
WCPU-3	Toilet - Public, 3m2	Yes	Share	1 x 3	1 x 3	Optional as visitor amenities may be shared with other services
WCAC	Toilet - Accessible, 6m2	Yes	Share	Share	1 x 6	Optional as visitor amenities may be shared with other services.
	Discounted Circulation %		25	32	32-35	

TREATMENT AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Chairs	Qty x m2 4 Chairs	Qty x m2 6 Chairs	Remarks
DENSR-14	Dental Surgery, 14m2	Yes	2 x 14	3 x 14	3 x 14	
DENSR-16	Dental Surgery, 16m2	Yes	-	1 x 16	1 x 16	Bed access, only if required. An additional 2m2 may be required should a wheelchair lifter be needed.
	Dental Surgery - 2 chairs		-	-	1 x 34	
PBTR-H-6	Patient Bay - Holding, 6m2	Yes	-	-	6	Optional. Provide 6m2 per chair for patient recovery if a dedicated service provided.
BHWS-B	Bay - Handwashing, Type B	Yes		1 x 1	1 x 1	Collocate with Recovery if provided
BRES	Bay - Resuscitation	Yes	Share	1 x 1.5	1 x 1.5	Optional - dependent on Unit policy.
	Discounted Circulation %		25	32	32-35	

Australasian Health Facility Guidelines

SUPPORT AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Chairs	Qty x m2 4 Chairs	Qty x m2 6 Chairs	Remarks
	OPG Room		0	1 x 7	1 x 7	Optional
DENW	Dental Workroom	Yes	1 x 8	1 x 12	1 x 12	This is not intended as a laboratory which would be used for the manufacture of prosthetics. Details of requirements for a Dental Laboratory have been included in Non-Standard Components.
	Instrument Reprocessing		1 x 10	1 x 12	1 x 20	
STGN-8	Store - General, 8m2	Yes	1 x 4	1 x 6	1 x 8	Sterile stock storage
CLRM-5	Clean-up Room, 5m2	Yes	1 x 7	1 x 7	1 x 7	For fluids disposal, soiled linen holding etc.
BLIN	Bay - Linen	Yes	1 x 2	1 x 2	1 x 2	
STGN-9	Store - General, 9m2		1 x 9	1 x 12	1 x 14	
CLRM-5	Cleaners' Room, 5m2	Yes	Share	1 x 5	1 x 5	Optional - may be shared with other services if collocated in a CHC or MHPS
	Plant Room		1 x 9	1 x 9	1 x 12	After-hours access
	Goods Reception / Loading		0	1 x 15	1 x 15	Space for one truck - dependent on model
	Discounted Circulation %		25	32	32-35	

STAFF AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Chairs	Qty x m2 4 Chairs	Qty x m2 6 Chairs	Remarks
OFF-S9	Office - Single Person, 9m2	Yes	1 x 9	1 x 9	1 x 9	Senior dentist
	Office - Workstation, 5.5m2		5.5	5.5	5.5	Number to suit shared access by staff for administration etc.
MEET-L-20	Meeting Room, 20m2	Yes	0	1 x 15	1 x 20	Suitable for videoconferencing unless provided nearby.
SRM-15	Staff Room, 15m2	Yes	0	1 x 12	1 x 15	May be shared in a CHC
BBEV-OP	Bay - Beverage, Open Plan	Yes	1 x 3	0	0	
PROP-2	Staff Property Bay - Staff	Yes	1 x 1	1 x 2	1 x 3	
SHST	Shower - Staff, 3m2	Yes	0	1 x 3	1 x 3	Can be shared if provided in a CHC.
WCST	Toilet - Staff, 3m2	Yes	1 x 3	1 x 3	1 x 3	Number dependent on staff numbers
	Discounted Circulation %		25	32	32-35	