

## 05 APPENDICES

### 5.1 SCHEDULE OF ACCOMODATION

---

The application of the schedule of accommodation below will require confirmation of the total ICU capacity requirements through detailed clinical services planning and required pod size for larger units.

The schedule of accommodation provided is based on the following indicatively sized ICUs:

- 14 bed Paediatric Intensive Care Unit
- 14 bed Adult Intensive Care Unit
- 56 bed Adult Intensive Care Unit (assumed to be configured as 4 pods of 14 beds).

As noted each pod will require dedicated clinical support space to ensure that materials are close to hand and staff travel time is minimised, however a number of assumptions are noted regarding opportunities to share some support areas between pods.

The space allocated to staff and support areas will need to reflect bed numbers, the arrangement of the beds and staffing profiles.

The 'Room/Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

**ENTRY / WAITING AND FAMILY SUPPORT AREAS**

AusHFG Room Code	Room / Space	SC / SC-D	PICU - 14 beds		Adult ICU - 14 beds		Adult ICU - 56 beds (4 pods)		Remarks
			Qty	m2	Qty	m2	Qty	m2	
RECL-12	Reception / Clerical	Yes	1	10 (o)	1	10 (o)	1	12	Optional. Provision will depend on the size of the unit and staffing arrangements.
WAIT-10	Waiting	Yes	1	15	1	15	1	40	Nominal area. To be calculated at 1.2m2 per able-bodied person, 1.5m2 per wheelchair occupant.
PLAP-10	Play Area - Paediatric	Yes	1	10 (o)	Shared		1	10 (o)	Optional.
BVM-3	Bay - Vending Machine	Yes	1	2	1	2	1	4	Locate close to but not within waiting area given level of noise and heat generation.
BWD-1	Bay - Water Dispenser	Yes	1	1	1	1	1	1	
BBEV-OP	Bay - Beverage, Open Plan	Yes					1	4	
WCPU-3	Toilet - Public	Yes	1	3	1	3	4	3	
WCAC	Toilet- Accessible	Yes	1	6 (o)	1	6 (o)	1	6 (o)	Optional. Include if not located nearby.
PAR	Parenting Room	Yes	1	6 (o)	1	6 (o)	1	6 (o)	Optional. Include if not located nearby.
INTF	Interview Room	Yes	1	14	1	14	3	14	For interviews with relatives. Include dual egress. Consider including some interview rooms within the clinical zone.
MEET-L-20	Meeting Room	Yes	1	20 (o)	1	20 (o)	1	20	Multifunctional meeting room for family and staff meetings. Larger meeting room frequently required for end of life discussions.
OVBR	Overnight Stay - Bedroom	Yes	2	10	1	10	3	10	For families. Provision depends on local operational policies. May be designed for use during the day as overflow interview rooms
OVES	Overnight Stay - Ensuite	Yes	2	4	1	4	3	4	
PROP-2	Property Bay	Yes	1	1 (o)	1	1 (o)	1	2 (o)	Optional. For family / visitor belongings if using overnight stay rooms as multipurpose spaces.
	Discounted Circulation %			25%		25%		25%	

**PATIENT AREAS**

AusHFG Room Code	Room / Space	SC / SC-D	PICU - 14 beds		Adult ICU - 14 beds		Adult ICU - 56 beds (4 pods)		Remarks
			Qty	m2	Qty	m2	Qty	m2	
1BR-IC	1 Bed Room - Intensive Care	Yes	7	25	13	25	50	25	The number of enclosed vs open bays provided will depend on the patient cohort and infection control considerations. Includes provision for a palliative care space.
PBIC	Patient Bay - Intensive Care	Yes	6	24.5		24.5		24.5	
1BR-IC	1 Bed Room - Intensive Care (Class N Isolation)	Yes	1	25	1	25	4	25	No. dependent on patient cohort and local jurisdictional policies.
1BR-IC	1 Bed Room - Intensive Care (Class P Isolation)	Yes		25 (o)		25 (o)	2	25 (o)	Optional. Depends on cohort and local jurisdictional requirements.
ANRM	Anteroom	Yes	1	6	1	6	4	6	Attached to 1 Bed Rooms - Isolation Class N (neg pressure ventilation).
BATH	Bathroom	Yes	1	15	1	15	2	15	Requires gases. May be shared between 2 pods subject to design.
ENS-SP	Ensuite - Special	Yes	2	6	2	6	8	6	Ensuites dedicated to negative pressure, positive pressure and standard isolation rooms. Number dependent on isolation room requirements. PICUs should include bathrooms with baths for younger children.
ENS-SP	Ensuite - Special	Yes	3	6	3	6	12	6	Ensuites to be shared between remaining rooms (1:4 ratio). PICUs should include bathrooms with baths for younger children.
SSTN-20	Staff Station	Yes	1	25	1	25	4	25	1 central staff station per pod.
OFF-CLN	Office – Clinical Workroom	Yes	1	15	1	15	4	15	1 per pod.
	Decentralised Staff Workstation		4	2	7	2	28	2	1 between 2 enclosed rooms.
BHWS-A	Bay - Handwashing, Type A	Yes	2	1	2	1	8	1	Also included within each patient bay.
BLIN	Bay - Linen	Yes	1	2	1	2	4	2	1 per pod.
BRES	Bay - Resuscitation	Yes	1	1.5	1	1.5	4	1.5	1 per pod.
BPATH	Bay - Pathology	Yes	1	3	1	3	4	3	1 per pod. May be shared between 2 pods depending on layout.
BPTS	Bay - Pneumatic Tube	Yes	1	1	1	1	4	1	1 per pod.
BMEQ-4	Bay - Mobile Equipment	Yes	3	4	3	4	12	4	3 per pod. Locate in quiet low traffic areas.
BBW	Bay - Blanket / Fluid Warming	Yes	1	1	1	1	2	1	Shared between 2 pods if collocated, subject to design.
	Discounted Circulation %			40%		40%		40%	

**SUPPORT AREAS**

AusHFG Room Code	Room / Space	SC / SC-D	PICU - 14 beds		Adult ICU - 14 beds		Adult ICU - 56 beds (4 pods)		Remarks
			Qty	m2	Qty	m2	Qty	m2	
BBEV-OP	Bay - Beverage, Open Plan	Yes	1	4	1	4	2	4	Share between 2 pods where collocated.
BMT-4	Bay - Meal Trolley	Yes	1	4 (o)	1	4 (o)	2	4 (o)	Optional. Depends on local operational policy for food services. Share between 2 pods where collocated.
	Formula Room		1	9					Used for formula preparation and storage, and sterilising of expressing equipment within PICUs.
STDR-10	Medication Room	Yes	1	12	1	12	2	20	Share between 2 pods where collocated. Area to be distributed if automated dispensing units are provided centrally within central staff area.
	Store - Clean		1	30	1	30	2	60	Clean stock. Distribution between pods dependent on layout.
STEQ-20	Store - Equipment	Yes	1	28	1	28	1	112	2m2 per bed. May include specialty stores eg for retrieval equipment, renal, allied health etc.
STGN-9	Store - General	Yes	1	14	1	14	2	28	
	Respiratory / Biomedical Workroom		1	12	1	12	1	20	For set up and servicing.
DTUR-12	Dirty Utility	Yes	1	12	1	12	4	12	1 per pod.
CLUP-7	Clean-Up Room	Yes	1	7	1	7	1	24	
CLRM-5	Cleaner's Room	Yes	1	5	1	5	4	5	Number and distribution depends on layout.
DISP-10	Disposal Room	Yes	1	8	1	8	1	20	
	Simulation Room		1	25 (o)			1	25 (o)	Optional. Requirement will depend on education and training requirements / access to central simulation facilities.
	Simulation Control Room						1	10 (o)	Optional.
	Workroom - Telehealth		1	12 (o)	1	12 (o)	1	12	Optional. Inclusion depends on operational guideline of unit. Can be used for viewing medical images and discussions, and for telehealth activities for liaison regarding transfers, virtual rounds etc.
WCST	Toilet - Staff	Yes	2	3	2	3	6	3	For ease of access from clinical areas.
	Discounted Circulation %			40%		40%		40%	

**STAFF AREAS**

AusHFG Room Code	Room / Space	SC / SC-D	PICU - 14 beds		Adult ICU - 14 beds		Adult ICU - 56 beds (4 pods)		Remarks
			Qty	m2	Qty	m2	Qty	m2	
OFF-S9	Office - Single Person, 9m2	Yes		9		9		9	Allocation will be dependent on staff profile and jurisdictional policies relating to staff work areas.
OFF-S12	Office - Single Person, 12m2	Yes		12		12		12	Allocation will be dependent on staff profile and jurisdictional policies relating to staff work areas.
	Office - Workstation, 4.4m2			4.4		4.4		4.4	Allocation will be dependent on staff profile and jurisdictional policies relating to staff work areas.
	Office - Workstation, 5.5m2			5.5		5.5		5.5	Allocation will be dependent on staff profile and jurisdictional policies relating to staff work areas.
MEET-L-15	Meeting Room	Yes	1	15	1	15	1	12	
MEET-L-20	Meeting Room	Yes	Shared		Shared		1	20	Assume shared access to 20m2 meeting room under Entry / Waiting & Family Support for smaller services.
MEET-L-55	Meeting Room	Yes					1	50	
STPS-8	Store - Photocopy / Stationery	Yes	1	5	1	5	2	8	
SRM-18	Staff Room	Yes	1	18	1	18	1	60	
CHST-10	Change - Staff (Male / Female)	Yes	1	10	1	10	1	40	Includes toilets, showers, lockers; size depends on the staffing per shift. (Female)
CHST-10	Change - Staff (Male / Female)	Yes	1	8	1	8	1	32	Includes toilets, showers, lockers; size depends on staffing per shift. (Male)
WCAC	Toilet - Accessible	Yes	Shared		Shared		1	6	
OVBR	Overnight Stay - Bedroom	Yes	1	10 (o)	1	10 (o)	1	10 (o)	Optional. Requirement depends on staffing arrangements. Close access to toilet / shower facilities required.
	Discounted Circulation %			25%		25%		25%	