

AX APPENDICES

AX.01 Schedule of Accommodation

A generic Schedule of Accommodation for a combined ICU/ SCN at levels 4/5/6 is shown below and lists generic spaces for this HPU.

For level 1 to 3 and a level 4 with only SCN requirements, refer to AHIA, 2012, AusHFG Part B: HPU 510 Maternity Unit.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

ENTRY / RECEPTION AREA

AusHFG Code	Room	Room / Space	SC / SC-D	Qty	m2	Remarks
		Bay - Lockers		1	1	Optional; for visitors' use
CONS		Consult Room	Yes	1	12	No. to be determined. Size based on Paediatric use. Will require heat table and scales.
INTF		Interview Room	Yes	2	12	
RECL-12		Reception / Clerical, 12m2	Yes	1	12	For 1 - 2 staff. Visitors will have access to hand hygiene at entry, in Family Support Areas and at each bed space
STPS-8		Store - Photocopy / Stationery, 8m2	Yes	1	8	Optional. May not be duplicated if provided in Staff Area
WCAC		Toilet - Accessible, 6m2	Yes	1	6	
WAIT-20		Waiting, 20m2	Yes	1	20	Designed to enable separation of family groups. May include phones and vending
		Discounted Circulation			25%	

Note: Assumes public amenities will be available nearby.

INPATIENT AREAS

AusHFG Code	Room	Room / Space	SC / SC-D	Qty	m2	Remarks
ANRM		Anteroom	Yes	2	6	As required for Class N Isolation Rooms
BAEX-12		Bathing / Examination Area		1	15	
BHWS-PPE		Bay - Handwashing / PPE	Yes	15	1.5	Type A basins. Assigned at a rate of 1:2 in ICU and 1:4 in HDU / SC beds.
NBSC		Neonatal Bay - Special Care	Yes	16	16	Area excludes basins. Sizes as per ICU to accommodate CPAP etc. High dependency care.
NBGC		Neonatal Bay - General Care	Yes	14	10	Excludes basins & circulation
NBICU		Neonatal Bay - Intensive Care	Yes	16	16	Area excludes basins.
		Neonatal Bay - Intensive Care, Isolation, Negative Pressure		2	17	Includes basin.
		Neonatal Bay - Intensive Care, Isolation, Standard		6	17	Includes basin.
PROC-20		Procedure Room	Yes	1	20	
		Discounted Circulation			25%	

Australasian Health Facility Guidelines

CLINICAL SUPPORT

AusHFG Code	Room	Room / Space	SC / SC-D	Qty	m2	Remarks
BPATH		Bay - Pathology	Yes	1	4	Bench 1200 x 800; analysers, ice machine, handbasin and pneumatic tube station.
CLUR-14		Clean Utility, 14m2	Yes	1	14	Includes medications
DTUR-10		Dirty Utility, 10m2	Yes	1	10	Includes medications
CLRM-5		Cleaner's Room, 5m2	Yes	1	5	
		Disposal Room, 10m2		1	10	
ECL-14		Equipment Clean-Up, 14m2	Yes	1	14	For cleaning beds, incubators, dismantling & cleaning respiratory equipment.
		Linen Cupboard	Yes	1	1	Optional. For small items that are not processed by the Linen Service - baby clothes etc
		Milk Storage Room		1	12	With refrigerators and freezers. Staff only area
FORM		Formula Room	Yes	1	9	Used for formula preparation and storage. Also used by mothers to sterilize expressing equipment.
BMEQ-4		Bay - Mobile Equipment, 4m2	Yes	4	4	General storage eg. Trolleys
BMEQ-6		Bay - Mobile Equipment, 6m2	Yes	1	6	X-Ray / Ultrasound
OFF-CLW		Office - Clinical Workroom	Yes	1	15	
SSTN-20		Staff Station, 20m2	Yes	1	20	Number dependent on layout.
STSS-24		Store - Sterile Stock, 24m2	Yes	1	25	Based on 0.5m2 per cot. Assumes compactus
STEQ-20		Store - Equipment, 20m2	Yes	1	100	Based on 2m2 per bed. Include space for biomedical assessment & repair
STGN-9		Store - General, 9m2	Yes	1	9	
		Store - Intra-Hospital Transport Equipment		1	8	
BMEQ-6		Bay - Mobile Equipment, 6m2	Yes	1	6	Intra-hospital equipment
STGN-8		Store - Retrieval Equipment	Yes	1	0	Space requirements will depend on the role of the retrieval service. Refer 390.06.25.
		Discounted Circulation			40%	

FAMILY SUPPORT AREAS

AusHFG Code	Room	Room / Space	SC / SC-D	Qty	m2	Remarks
PLAP-10		Play Area - Paediatric, 10m2	Yes	1	10	For siblings.
FEED		Feeding Room	Yes	1	12	For expressing milk & breast feeding; 3-4 mothers
LAUN-PT		Laundry - Domestic	Yes	1	6	Baby and parent clothing. Incorporate linen cupboard for small items
		Parent / Infant Room		6	15	May accommodate parents and newborns.
		Parent Resource Area		1	9	Quiet room for use of laptop, literature or other resources
WCPU-3		Toilet - Public, 3m2	Yes	1	3	To be located in ready access to inpatient areas
ENST-ST-C		Ensuite - Standard - Additional Access, 5m2	Yes	3	5	Shared between 2 rooms. Provision of an accessible ensuite will be needed.
		Laundry - Domestic		1	6	Optional. Baby and parent clothing. Incorporate linen cupboard for small items.
PROP-2		Property Bay - Staff	Yes	1	8	Approximately 50 half height lockers
		Discounted Circulation			25%	

The number of Parent / Infant Rooms to be provided will be determined on a jurisdictional basis. The number shown in this Schedule of Accommodation is indicative only.

STAFF OFFICES AND AMENITIES

AusHFG Code	Room	Room / Space	SC / SC-D	Qty	m2	Remarks
OFF-S12		Office - Single Person, 12m2	Yes	1	12	Clinical Director
OFF-S9		Office - Single Person, 9m2	Yes	1	9	Staff Specialist (full time), NUM
OFF-2P		Office - 2 Person Shared, 12m2	Yes	1	12	Social Workers
		Office - Workstation, 5.5m2		1	5.5	eg. Administration, CNC and research staff
		Office - Workstation, 4.4m2		1	4.4	eg. Allied health, CNE, registrars, research staff. Data entry etc.
OVBR		Overnight Stay - Bedroom	Yes	1	10	Optional and dependent on rostering practices.
MEET-L-30		Meeting Room, 30m2	Yes	1	30	Up to 20 staff
SHST		Shower - Staff, 3m2	Yes	1	3	
SRM-18		Staff Room	Yes	1	40	
STPS-8		Store - Photocopy / Stationery, 8m2		1	8	
STGN-9		Store - General, 9m2	Yes	1	9	
MEET-L-20		Meeting Room, 20m2	Yes	1	20	Low fidelity simulation. Adjacent to Tutorial Room. Operable wall optional. Provide medical gases.
		Staff Workroom - Telemedicine		1	12	For 3 to 4 staff
WCST		Toilet - Staff, 3m2	Yes	4	3	
PROP-2		Property Bay - Staff	Yes	1	8	Approximately 50 half height lockers
		Discounted Circulation			25%	

These office allocations are indicative only. Each project will be required to develop a workforce profile to inform the development of space for offices.