

## AX APPENDICES

### AX.01 Schedule of Accommodation

A Schedule of Accommodation is attached for a Level 4 Unit assuming a nine body hold store. It is likely that all hospital sites will require some level of Hospital Mortuary facilities for body holding and viewing. Capacity will be dependent on anticipated throughput.

A vehicle bay will be provided in an external weatherproof area adjacent to the Mortuary which provides waiting space and parking for funeral directors vehicle and other vehicles which is screened from public view.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

#### ENTRY LOBBY / ADMINISTRATION / EXIT LOBBY

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
	Entry Lobby		1 x 7	May contain weigh station in the case of Units with an Autopsy Suite
OFF-S9	Office - Single Person, 9m2	Yes	1 x 9	Space for administration duties plus lockable cupboard for valuables
	Bay - Mortuary Trolley Parking		1 x 3	
MOR-EX	Exit - Mortuary	Yes	1 x 7	
	Discounted Circulation		20%	

Note: Provision of a weather protected parking bay for funeral directors vehicles is required.

**BODY HOLDING**

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
MOR-CS	Cool Store (Body Holding)	Yes	1 x 25	Assumes 9 bodies on either racks or individual cabinets (3x3 tiers). Space allocation includes manoeuvring/ loading space.
BHWS-B	Bay - Handwashing, Type B	Yes	1	
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	1 x 4	Provides store and recharging bay for lifting equipment used in Cool Store.
	Procedure Room - Mortuary		1 x 20	Optional and provided when an Autopsy Unit is not required yet there is some requirement to collect clinical information. Referred to as visual examinations.
BPPE	Bay - PPE	Yes	1 x 3	Includes storage for PPE and linen.
STGN-9	Store - General, 9m2	Yes	1 x 9	Consumables
WCST	Toilet - Staff, 3m2	Yes	1 x 3	Unisex; only provided where Autopsy Unit is not collocated as additional amenities provided in this circumstance.
CLRM-5	Cleaners Room, 5m2	Yes	1 x 5	Shared with Autopsy Suite if provided.
DISP-8	Disposal Room, 8m2		1 x 8	Shared with Autopsy Unit if provided
	Discounted Circulation		20%	

**WAITING / VIEWING**

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
MOR-W	Mortuary Waiting	Yes	1 x 9	Accommodates up to 5 people
WAIT-SUB	Waiting Area – Sub, 5m2	Yes	1 x 5	Attached to viewing room
	Outdoor Area		1 x 15	Optional and not routinely provided
MOR-VR	Viewing Room	Yes	1 x 10	
WCAC	Toilet - Accessible, 6m2	Yes	1 x 6	Optional. Not included if an alternate located nearby
	Discounted Circulation		20%	

**MORTUARY - ONE-ROOM AUTOPSY UNIT**

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
MOR-AU	Autopsy Room	Yes	1 x 30	Autopsy bench / trolley, dissection bench, storage for containers
	Store - Tissue Samples		1 x 6	Storage of tissue samples etc until they can be disposed of.
	Store - Flammable Liquids		1 x 1	Flammable cupboard
BES	Bay - Emergency Shower		1 x 2	
MOR-CU	Mortuary - Clean-Up Area	Yes	1 x 9	Includes sink, storage and a utensil washer
	Observation Area		1 x 10	Seating for 6-7 observers
CHST-10	Change - Staff (Male/ Female), 10m2		2 x 8	Male and female (if required) includes property locker (full length lockers and hooks), shower, toilet and bench.
	Discounted Circulation		20%	

Autopsy Unit inclusion will be dependent on the service model.

Notes:

- Type of body storage will influence allocated space.
- Number of autopsy rooms will also determine need for an office, size of change rooms etc.