



1 Bed Room - Mental Health, Nested Ensuite

Room Code	1BR-MH-NE
Briefed Area	15.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff; 1-2 visitors
Hours of Operation	24 hours

Description | The 1 Bed Room - Mental Health, Inboard provides a single occupancy bedroom for mental health inpatients. The nested ensuite layout is used in conjunction with the Ensuite - Mental Health, Nested (ENS-MH-NE). Alternatively, a nested ensuite layout may be provided (see 1BR-MH-IN).

Electrical	PROTECTION: body protected	<input checked="" type="checkbox"/>	HVAC	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
Lighting	LIGHTING: general	<input checked="" type="checkbox"/>	Medical Gas	AIRCONDITIONING: positive pressure	<input type="checkbox"/>
	LIGHTING: colour corrected	<input type="checkbox"/>		AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	LIGHTING: dimmable	<input type="checkbox"/>		VENTILATION: exhaust	<input type="checkbox"/>
	LIGHTING: indirect	<input type="checkbox"/>		VENTILATION: supply	<input type="checkbox"/>
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	<input checked="" type="checkbox"/>		VENTILATION: natural	<input type="checkbox"/>
	NURSE CALL SYSTEM: annunciator	<input type="checkbox"/>		MEDICAL GAS: general anaesthesia	<input type="checkbox"/>
	DURESS: fixed	<input type="checkbox"/>		MEDICAL GAS: special care	<input type="checkbox"/>
	DURESS: wireless coverage	<input checked="" type="checkbox"/>		MEDICAL GAS: special care, neonatal ventilation	<input type="checkbox"/>
Security	ACCESS CONTROL: to door	<input type="checkbox"/>		MEDICAL GAS: birthing	<input type="checkbox"/>
	ACCESS CONTROL: to item / joinery	<input type="checkbox"/>	Hydraulic	WATER: drinking	<input type="checkbox"/>
	INTERCOM: service communications	<input type="checkbox"/>		WATER: specialty	<input type="checkbox"/>
	INTERCOM: security and access control	<input type="checkbox"/>		DRAINAGE: sanitary	<input type="checkbox"/>
	CCTV: camera coverage within room	<input type="checkbox"/>		DRAINAGE: specialty	<input type="checkbox"/>
	INTRUSION DETECTION: door monitoring	<input type="checkbox"/>	Fire	DETECTION: smoke	<input checked="" type="checkbox"/>
	INTRUSION DETECTION: spatial monitoring	<input type="checkbox"/>		DETECTION: heat	<input type="checkbox"/>
ICT and Audio Visual	AUDIO VISUAL: patient entertainment system	<input type="checkbox"/>	Shielding	SHIELDING: ionising radiation	<input type="checkbox"/>
	AUDIO VISUAL: visitor experience system	<input type="checkbox"/>		SHIELDING: magentic and radio frequency	<input type="checkbox"/>
	AUDIO VISUAL: virtual collaboration system	<input type="checkbox"/>	Acoustics	SPEECH PRIVACY:	
	AUDIO VISUAL: clinical support system	<input type="checkbox"/>		not private moderate private confidential	
	AUDIO VISUAL: digital operating room system	<input type="checkbox"/>		NOISE SENSITIVITY:	
Accessibility	AUDIO: hearing augmentation	<input type="checkbox"/>		not sensitive medium sensitive sensitive	
	VISUAL: luminance contrast	<input checked="" type="checkbox"/>		NOISE GENERATION:	
	SIGNAGE: accessible, statutory	<input type="checkbox"/>		low moderate high very high	

Additional Considerations

- All fittings and fixtures used in bedrooms must be of a type manufactured and marketed as anti-ligature. Requirements for the selection of suitable finishes, hardware, fixtures and fittings (including any weight limits for load release for certain fixtures) must be confirmed at project level based on service requirements, patient safety policies, local design guidance, risk assessments and confirmation of operational models. This includes the door, door hardware, joinery surfaces, joinery hardware, engineering services outlets and any ceiling mounted fixtures and services. All tamper proof and anti-ligature items must be installed in accordance with their manufacturer's instructions.

- Where an accessible bedroom is required to be provided, anti-ligature fittings may require a performance solution to be provided in order for the room to meet accessibility requirements. This must be considered and addressed at project level to meet applicable legislation and standards (to be confirmed with the project accessibility and building code consultants).
- All glazing (including external windows) is to be Grade A safety glass to comply with AS/NZS 2208 and AS 1288. Toughened and laminated glass with a structural interlayer is recommended. Additional requirements for glazing are to be confirmed at project level to suit the specific mental health environment (i.e. non-acute, acute, intensive care).
- Window size and minimum sill height are to be confirmed at project level to ensure access to natural daylight and external views from the bed and seating areas within the room. Type of blinds (e.g. integral venetians, integral blackout, etc.) to be confirmed at project level.
- Doors should support consumer safety, dignity and wellbeing, and be non-institutional in appearance to the extent possible. It is recommended that the door set is selected as a full assembly to ensure the leaf, frame and hardware are coordinated and meet all tamper proof, anti-ligature and anti-barricade requirements when used together. Project should consider the use of prototypes to confirm solution to address all requirements.
- The inclusion of door top or top and side anti-ligature alarms connected to the emergency call/duress systems may be considered and assessed at project level to suit service requirements.
- Vision panel is provided for observation checks by staff in consultation with the consumer. Inclusion and size of vision panel to be confirmed to suit service requirements. Controls for integral blind to be provided to both bedroom and corridor sides of the vision panel. Switchable glass may be provided in lieu of integral blind. Placement of vision panel to be confirmed to support requirements for observation.
- Rooms are to be lockable from the bedroom side, with staff override/master key access from the outside.
- The ergonomic operation of the door hardware/handles is to be considered as some products are difficult to grip for those with limited hand function.
- Access control devices, such as card/wristband readers, are optional and provision is dependent on service requirements and operational models. Support for programming and provision of devices is required for implementation.
- Based on a risk assessment, ceiling height is to be confirmed at a project level in combination with considerations for FF&E selection to ensure consumers cannot reach or cause damage to the ceiling or services located on the ceiling.
- Unique considerations for Intensive Care and Child and Adolescent areas are to be confirmed at project level to suit jurisdictional policies
- The selection of finishes in rooms for mental health units is to be carefully considered to support the provision of a welcoming, warm and therapeutic atmosphere and should aim to eliminate an institutional feel. Flooring and skirting selections are to be considered at project level based on risk assessment for provision of alternative options (e.g. timber/MDF skirting in lieu of coved skirtings).
- Bed may alternatively be provided as a fixed plinth type instead of adjustable height electric bed, depending on service requirements. Clearances around bed to be maintained.
- Configuration and size of wardrobe is to be confirmed at project level to suit consumer property storage requirements.
- Provision of safe within the wardrobe joinery is optional and provision is dependent on operational models for property storage. Where provided, shelves will need to be reinforced.
- Lighting configuration and types (general room, reading, task, night lights, sensory, etc.) to be confirmed at project level. Access and type of switch controls to be determined to suit requirements.
- Staff assist and emergency call buttons have not been indicated in this Standard Component on the assumption that a portable call and duress devices are provided to staff, and projects must confirm requirements based on operational models.
- Consider the location of wi-fi access points to ensure strong coverage is provided for mobile duress functions.
- The provision of USB outlets is to be determined at project level to suit local jurisdictional requirements.
- Provision of wall mounted television/patient entertainment systems are to be considered and confirmed at project level to suit local jurisdictional and operational service requirements. If provided, ensure that the screen is recessed or within an enclosure with tamper proof fittings and sufficient ventilation.
- Provision of radar assist sensors to detect falls and monitor high risk behaviour patterns may be considered at project level to suit local jurisdictional and operational service requirements.
- Co-ordination of the ceiling services on the ceiling is required. It is ideal to reduce visual 'clutter' over the bed and place services out of reach from raised fixed surfaces (e.g. bench). Removal of emergency warning equipment such as speakers/strobes may be considered via a performance solution to patient rooms to reduce the number of services provided on the ceiling within the room. All fixtures provided (lights, air conditioning grilles, detectors, wireless access points) are to be recessed with tamper proof fittings.
- Anti-pick caulking is recommended for finishing between surfaces.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-017.12	DOOR: hinged, 1 leaf, 1100 clear opening, solid, anti-ligature and anti-barricade, standard vision panel, with integral blind	inclusion and size of vision panel to be confirmed to suit service requirements; controls for integral blind to be provided to both bedroom and corridor sides of the vision panel; switchable glass may be provided in lieu of integral blind; additional requirements for glazing in vision panel to be confirmed to suit the mental health environment
AFDPR-006.05	DOOR PROTECTION: plate, full height	optional; provision dependent on leaf material and finish
ITSE-261	READER: security, access control, proximity card, wall mounted	optional; outside door for card/wristband swipe access; provision dependant clinical service requirements and operational models; door mounted hardware is also acceptable
DOHI-002.03	DOOR: hinged, 1 leaf, 850 clear opening, solid, anti-ligature	to ensuite (see ENS-MH-IN); with angled cut down from top; may alternatively be provided as magnetic leaf/saloon style doors
WIOP-255.03	WINDOW: operable, jockey sash, external, double glazed, sill at 600H, with integral blind, tamper proof, anti-ligature	operability (jockey sash) as required to allow maintenance of integral blind; additional requirements for glazing to be confirmed to suit the mental health environment



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-102	FLOOR FINISH: vinyl, seamless, standard slip resistance, cushioned	
FLSK-022	SKIRTING: vinyl, integral with floor vinyl, coved, tamper proof, anti-ligature	
WLFI-002	WALL FINISH: paint, clinical areas	
CLFS-011	CEILING: flush set, suspended	
CLCN-031	CORNICE: square set	



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-011	BENCH: 500D, laminate	①	1	
JOBH-022	BEDHEAD: full height, tamper proof, anti-ligature	①	1	
JOCU-406	WARDROBE: built-in, open, fixed shelves, tamper proof, anti-ligature	①	1	
JOGE-001	BULKHEAD: joinery	①	1	to wardrobe



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-057	NOTICEBOARD: fixed, fabric covered, tamper proof, anti-ligature	②	1	to bench; material and method for attaching items to be confirmed to suit operational models
FIBM-107	MIRROR: fixed, safety glass, toughened and laminated, frameless, recessed, tamper proof, anti-ligature	①	1	optional
FQBS-111	CHAIR: visitor, mental health	③	1	
FQBS-354	LOUNGE: ottoman	③	1	

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQSN-107	BEDSIDE TABLE: fixed, patient locker, tamper proof, anti-ligature	③	1	
FQSN-123	SAFE: small, integral to joinery	①	1	optional; to wardrobe; provision dependent on operational models for property storage
MMBE-141	BED: patient, electric, with mattress, mental health	③	1	may alternatively be provided as a fixed plinth type bed depending on service requirements



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	①	1	low height, for bed
ELGP-201	GPO: double, wall mounted	①	2	1 to bedhead, 1 to bench
ELSW-001	SWITCH: light	①	3	2 for general room lights (1 to entry and 1 to bedhead), 1 for ensuite lights, 1 for light over bench
ELSW-002	SWITCH: light, 2-gang	①	1	optional; required for reading light and night light if provided; to bedhead
ITCL-126	BUTTON: nurse call, patient to staff call, with cancel, joinery mounted	①	1	
LIFX-156	LIGHT: night, wall recessed, tamper proof, anti-ligature	①	1	optional; control to bedhead; an additional control may be provided outside the bedroom to support staff observation (restriction of access to external light control must be considered)
LIFX-168	LIGHT: reading, ceiling recessed, tamper proof, anti-ligature	①	1	optional; may alternatively be integrated into the bedhead if provided