

Room Name	1 Bed Room - Inboard Ensuite		Room Number 1BR-ST
<b>Revision</b>	4		
<b>Issue Date</b>	22.06.2017		
<b>BRIEFING</b>			
<b>Briefed Area</b>	15.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 patient; 1-2 staff; 1-2 visitors		
<b>Acoustics</b>	Acoustic privacy is required		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	A 1 Bed Room will accommodate one patient for the delivery of nursing care and treatment; natural light and outlook is essential; requires ability to view out of the window from either the chair or the bed. The 1 Bed Room may also be used as an Isolation Room - Class S (Standard Pressure). Door glazing and an internal window is recommended with this option. The 1 Bed Room may vary in configuration to suit different Ensuite options including: inboard, outboard and shared ensuites.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
<b>Air</b>	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No	
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No	
	EXHAUST: room exhaust = No	VENTILATION = No	
<b>Lighting</b>	LIGHTING: colour corrected = Yes	LIGHTING: dimmable = No	
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No	
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No	
	LIGHTING: fluorescent, general = No	LIGHTING: indirect = No	
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes		

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	obs panel for isolation room use
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to 'Acrovyn'
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to 'Acrovyn'
FLVY-006	FLOOR FINISH: vinyl, seamless, coved, non slip, textured	under basin
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-002	OBSERVATION: internal window, alum/glass, door height, powdercoat	optional, to rooms with an outboard ensuite
DWOB-010	OBSERVATION: through door/s, glass, clear	for isolation room use
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
WLPR-012	WALL PROTECTION: corner guards, to 900 AFFL, prefinished PVC	where required
DWWH-005	WINDOW	natural light & outlook essential

**Room Name** | 1 Bed Room - Inboard Ensuite

**Room Number** 1BR-ST

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)
MMBE-016	BED: patient, manual	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
DWWD-007	BLIND: venetian, integral	1	1	if internal observation window provided, 2 way control
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FIHR-019	BRACKET: for suction bottle	2	1	
MMGE-019	CHAIR: patient	3	1	
FQBS-030	CHAIR: visitor, patient	3	1	
FIJO-130	CUPBOARD: tall, single door, adj shelves and clothes rail	1	1	wardrobe
FQGE-009	CURTAIN: bed screen	3	1	
DWWD-011	CURTAIN: window, drapes	3	1	set
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITBU-011	DISPLAY SCREEN: MATV	3	1	34cm screen, ceiling mounted
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FQSN-051	LOCKER: 2 drawers, open under, lockable, mobile	3	1	
FIJO-194	SHELF: laminate	1	1	for flowers
MMGE-100	SUCTION BOTTLE	3	1	
FQTA-013	TABLE: overbed	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIRT-021	TRACK: curtain, bedscreen	1	1	
FIRT-027	TRACK: curtain, box pelmet	1	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-123	GPO: emergency power, single, wall mounted	1	4	bedhead
ELGP-101	GPO: single, ceiling mounted	1	1	for ceiling mounted MATV display screen

**Room Name** | 1 Bed Room - Inboard Ensuite

**Room Number** 1BR-ST

AusHFG code	Description	Group	Qty	Comment
ELGP-109	GPO: single, wall mounted	1	1	bedhead low level, for electric bed
ELGP-109	GPO: single, wall mounted	1	4	bedhead
ELGP-109	GPO: single, wall mounted	1	1	adjacent to patient chair
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	+ light switch on the handset
LIFX-017	LIGHT: night light	1	1	
LIFX-011	LIGHT: reading light	1	1	up/down light
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-070	OUTLET: MATV	1	1	
MGAS-023	OUTLET: medical air (MA), wall mounted	1	1	
MGAS-043	OUTLET: oxygen (O2), wall mounted	1	1	
MGAS-063	OUTLET: suction, wall mounted	1	1	
ELPR-006	RCD: residual current device	1	1	
ELBO-015	SWITCH: light, single	1	4	