

| Room Name | ADL Bed Room | | Room Number ADLBR |
|---|---|---|-------------------|
| Revision | 3 | | |
| Issue Date | 20.03.17 | | |
| BRIEFING | | | |
| Briefed Area | 15.00 m ² | | |
| Hours of Operation | 8am to 6pm, intermittent use | | |
| Occupancy | 1 patient; 1-2 staff | | |
| Acoustics | Acoustic privacy is required | | |
| Remarks | | | |
| Description / Special Requirements | Single Bed Room for Activities of Daily Living patient assessment and training; natural light and outlook is desirable. The room is to be lockable. The room furnishings will be domestic style to mimic home conditions. | | |
| SERVICES | | | |
| General Requirements | BODY PROTECTED = Yes | CARDIAC PROTECTED = No | |
| Air | AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No | AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No | |
| Lighting | LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes | LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No | |
| Nurse Call | NURSE CALL SYSTEM = Yes | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|--|---------------------------------|
| CLFS-006 | CEILING: plasterboard, flush set, suspended, paint, washable | |
| CLCN-002 | CORNICE: aluminium, 24mm shadow angle, powdercoat | |
| DWSC-011 | DOOR: 1100mm c/o, single leaf, solid core, paint | lockable |
| DWPR-006 | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished | equal to 'Acrovyn' |
| DWPR-010 | DOOR PROTECTION: to door frame, PVC, prefinished | equal to 'Acrovyn' |
| FLCP-003 | FLOOR FINISH: carpet, broadloom, 48 oz., 90/10 wool/nylon | vinyl also acceptable |
| FLSK-009 | SKIRTING: vinyl, feather edged, 150H, prefinished | or floor vinyl covered skirting |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |
| DWWH-005 | WINDOW | desirable |

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|-----------------------------|
| FQBS-003 | BED: domestic, single | 3 | 1 | |
| MMGE-019 | CHAIR: patient | 3 | 1 | |
| FQBS-028 | CHAIR: visitor, clinical areas | 3 | 1 | |
| FIJO-130 | CUPBOARD: tall, single door, adj shelves and clothes rail | 1 | 1 | with hanging rail & shelves |
| DWWD-011 | CURTAIN: window, drapes | 3 | 2 | |

Room Name | **ADL Bed Room**
Room Number **ADLBR**

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--|-------|-----|--------------------|
| FQDW-001 | DESK: adj height, 1100W x 600D x 750H nom. | 3 | 1 | |
| FIBM-006 | MIRROR: fixed, glass | 1 | 1 | optional |
| FQTA-001 | TABLE: bedside | 3 | 1 | heavy |
| FIRT-027 | TRACK: curtain, box pelmet | 1 | 1 | to external window |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--|-------|-----|----------------------------|
| ITCL-006 | BUTTON: nurse call, patient to staff | 1 | 1 | + indicator button & light |
| ITCL-008 | BUTTON: nurse call, staff assist | 1 | 1 | + indicator button & light |
| ELGP-209.1 | GPO: double, wall mounted, RCD protected (V) | 1 | 1 | |
| ELGP-109 | GPO: single, wall mounted | 1 | 2 | |
| ELGP-110 | GPO: single, wall mounted, cleaner | 1 | 1 | |
| LIFX-011 | LIGHT: reading light | 1 | 1 | |
| ELBO-015 | SWITCH: light, single | 1 | 2 | |