

Room Name	ADL Dining / Lounge		Room Number ADLD
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	12.00 m ²		
Hours of Operation	24 Hours		
Occupancy	Up to 4		
Acoustics	sound attenuation level-high; acoustic privacy is required.		
Remarks			
Description / Special Requirements	The ADL Dining / Lounge Room is an area provided within the Transitional Living Unit for the patient along with their visitors to eat their meals, away from the bedroom environment. The Dining / Lounge Room may be located adjacent to the ADL Kitchen.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	
WLPR-021	WALL PROTECTION: crash rail, at 900 AFFL	optional
DWWH-005	WINDOW	desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQBS-010	CHAIR: armchair	3	2	
FQBS-015	CHAIR: dining	3	3	with space for wheelchair
FQTA-034	TABLE: rectangular, 900L x 600W, low height	3	1	
FQTA-055	TABLE: round, 900 diam, dining height	3	1	
DWWD-013	WINDOW DRESSING: external window	3	1	optional, to external window as required; number to suit window configuration

Room Name | ADL Dining / Lounge

Room Number ADLD

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	2	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-208	GPO: double, wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	1	