

Room Name	ADL Kitchen		Room Number ADLK
Revision	4		
Issue Date	26.04.2021		
BRIEFING			
Briefed Area	12.00 m ²		
Hours of Operation	up to 24 hours		
Occupancy	up to 2 patients, 1-2 staff		
Acoustics	Acoustics: sound attenuation level high.		
Remarks			
Description / Special Requirements	<p>The ADL Kitchen provides an accessible space for the training and assessment of patients in Activities of Daily Living (ADL) tasks. The space is to be functional for a range of patients including wheelchair users. The kitchen can include a combination of fittings and appliances such as a sink, cooktop, oven/grill, microwave and refrigerator to support common ADL training and assessment tasks as per service requirements. Room exhaust to be provided to range hood over cooktop.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. If multiple ADL rooms are combined into an ADL suite nurse call buttons can be rationalised into a central location. The room may be enclosed with a lockable door depending on security requirements. External outlook and access to natural light is desirable. 		
SERVICES			
Electrical	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	plasterboard flush set ceiling is also acceptable
CLCN-009	CORNICE: wall trim fixing	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; pendulum P3 or agreed equivalent around sink
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	
DWWH-005	WINDOW	desirable

Room Name | ADL Kitchen
Room Number ADLK
Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-020	BENCH: 600D, open under, laminate finish	1	2	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	2	
FQCW-016	BIN: waste, general, 20L	3	1	
DWWD-004	BLIND: roller	3	1	
FIJO-212	BULKHEAD: joinery	1	2	plasterboard bulkhead also acceptable
FQCA-089	COOKTOP: induction	1	1	controls to be located close to front
FIJO-205	CUPBOARD: drawer unit, single drawer, lockable	1	6	
FIJO-223	CUPBOARD: tall, oven cabinet	1	1	
FIJO-131	CUPBOARD: tall, single door, adj shelves, lockable	1	1	
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	1	
FIJO-156	CUPBOARD: wall mount, single door, adj shelves	1	2	
FIDI-025	DISPENSER: paper/hand towel	2	1	to sink
FIDI-030	DISPENSER: soap	2	1	to sink
FQCA-031	FRIDGE: domestic, 250L	3	1	
FQCA-046	KETTLE: electric	3	1	
FQCA-063	OVEN: electric	1	1	retractable/side opening doors
FQCA-067	OVEN: microwave, domestic	3	1	on bench
FIJO-213	PANEL: joinery carcass end	1	3	
FIJO-224	PANEL: joinery fixed panel	1	5	to sink and cooktop
FQSM-040	PEDESTAL: mobile, drawer unit, lockable, 660H	3	1	under bench
FQCA-072	RANGEHOOD	1	1	over cooktop
HYBA-041	SINK: double, with drainer, half size rinse bowl	1	1	heat lined, warm water
HYTP-040	TAPWARE: mixer, sink, accessible	1	1	
FQCA-080	TOASTER: domestic	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGE-001	DIRECT CONNECTION: power	1	2	to cooktop and oven
ELGP-208	GPO: double, wall mounted	1	4	
ELGP-109	GPO: single, wall mounted	1	2	to range hood and fridge
ELPR-006	RCD: residual current device	1	1	
ELBO-007	SWITCH: emergency isolation	1	1	to cooktop and oven
ELBO-015	SWITCH: light, single	1	1	