



Room Name	After Hours Drug Store	Room Number AHDR		
Revision	4			
Issue Date	18.01.2021			
BRIEFING				
Briefed Area	5.00 m ²			
Hours of Operation	24 Hours			
Occupancy	1 - 2 staff intermittently			
Acoustics				
Remarks				
Description / Special Requirements	Stock is replenished by pharmacy person access from within the pharmacy. Secure alarm may be required if room accessed the second sec	nel ar acces rom a	or the storage of medications that may be required after hound, depending on the location of the room, there may be direct to the room for authorised personnel is required. A durect public or patient care area. Refrigerated storage will be expecific requirements for automated medication managements.	rect ss
SERVICES				
General Requirements	BODY PROTECTED		CARDIAC PROTECTED	
Air	AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust	V	AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION	
Lighting	LIGHTING: colour corrected LIGHTING: downlights		LIGHTING: dimmable LIGHTING: downlights, dimmable	
	LIGHTING: fluorescent/LED, downlights		LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	
	LIGHTING: fluorescent/LED, general	V	LIGHTING: indirect	
Nurse Call	NURSE CALL SYSTEM			

Room Fabrics

AusHFG code	AusHFG code Description	
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-007	DOOR: 910mm c/o, single leaf, observation panel, solid core/safety glass, paint	optional, if room located with direct access from pharmacy
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	from corridor
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FIJO-212	BULKHEAD: joinery	1	1	plasterboard bulkhead also acceptable

AJJAHAA australoide heuth infrastructure ellicore controversi cu automatica de automatica montres Page: 1 Print Date: 14/01/2021





Room Name

After Hours Drug Store

Room Number AHDR

AusHFG code	Description	Group	Qty	Comment
ITSE-012	CAMERA: CCTV	1	1	optional, provision and placement dependent on local policies
FIJO-141	CUPBOARD: underbench, single door, adj shelves, lockable	1	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	2	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
MMGE-036	FRIDGE: drugs, underbench	3	1	
FQSM-045	SHELVING: storage solution, 400W x 600D x 2100H nom., wire, mobile	3	2	storage solution/mix of storage options to be tailored to suit project requirements

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	optional
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-123	GPO: emergency power, single, wall mounted	1	1	to drug fridge
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	to drug fridge, for temperature monitoring
ITSE-038	READER: access control, general	1	2	
ELBO-015	SWITCH: light, single	1	1	



Page: 2 Print Date: 14/01/2021