

Room Name | Airlock - Entry, 12m2

Room Number AIRLE-12

Revision 2
Issue Date 20.03.17

BRIEFING
Briefed Area
Hours of Operation
Occupancy
Acoustics
Remarks
Description / Special Requirements

 12.00 m²
 24 Hours

Airlock associated with a Main Entry Area for wind/ weather protection and to maintain air pressurisation. It will be used by a wide range of people including fully ambulant, persons using a wide range of walking aids, persons in wheelchairs or on trolleys and the general public. The size of the air lock should allow for several people to enter before the second door opens and should reflect the level of service provision. Entry doors may be glazed and automatic. Walls may also be glazed. After-hours access may require intercom or special security provisions.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = Yes
 AIRCONDITIONING: positive pressure = No
 EXHAUST: room exhaust = No

 AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: negative pressure = No
 VENTILATION = No

Lighting

 LIGHTING: colour corrected = No
 LIGHTING: downlights = No
 LIGHTING: fluorescent, downlights = No
 LIGHTING: fluorescent, general = Yes

 LIGHTING: dimmable = No
 LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-050	DOOR: 1600mm c/o, double leaf, fully glazed, alum/safety glass, powdercoat/paint	1600mm clear opening, may be automatic, lockable
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = vinyl, or other suitable slip resistant floor finish
FLGE-016	FLOOR MAT: recessed, composite slip resistant	Optional; attention to detailing of recessed mat to avoid trip hazard
FLSK-008	SKIRTING: to suit glazing system over	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQBS-007	BENCH SEAT: freestanding, indoor	1	1	Optional
FIHR-002	BRACKET: for CCTV camera, ceiling mounted	1	1	Optional
ITSE-012	CAMERA: CCTV	1	1	Optional
ITSE-048	DISPLAY SCREEN: CCTV system	3	1	Optional

Room Name | Airlock - Entry, 12m2

Room Number AIRLE-12

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-024	DOOR RELEASE: access control, emergency override	3	1	Optional
ELGP-101	GPO: single, ceiling mounted	1	1	Optional: CCTV camera, intercom
ELGP-101	GPO: single, ceiling mounted	1	2	
ITSE-028	INTERCOM: audiovisual, wall mounted	1	1	Optional, after hours access. Can be integral with CCTV system. If required, receiving location to be identified.
ITIN-011	OUTLET: data, single RJ45, ceiling mounted	1	1	
ITSE-038	READER: access control, general	1	1	Optional: swipe card access for staff 'after hours access'.