

Room Name | Airlock - Entry, 6m2

Room Number AIRLE-6

Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 6.00 m²
Hours of Operation 24 Hours

Occupancy
Acoustics
Remarks
**Description /
Special Requirements**

Airlock associated with a Main Entry Area for wind/ weather protection and to maintain air pressurisation. It will be used by a wide range of people including fully ambulant, persons using a wide range of walking aids, persons in wheelchairs or on trolleys and the general public. The size of the air lock should allow for several people to enter before the second door opens and should reflect the level of service provision. Entry doors may be glazed and automatic. Walls may also be glazed. After-hours access may require intercom or special security provisions.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = No

Air

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

Lighting

LIGHTING: colour corrected = No

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = Yes

LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-050	DOOR: 1600mm c/o, double leaf, fully glazed, alum/safety glass, powdercoat/paint	may be automatic, lockable
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = vinyl, or other suitable slip resistant floor finish
FLGE-016	FLOOR MAT: recessed, composite slip resistant	Optional; Attention to detailing of recessed mat to avoid trip hazard
FLSK-008	SKIRTING: to suit glazing system over	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIHR-002	BRACKET: for CCTV camera, ceiling mounted	1	1	
ITSE-012	CAMERA: CCTV	1	1	optional
ITSE-048	DISPLAY SCREEN: CCTV system	3	1	optional

Room Name | Airlock - Entry, 6m2

Room Number AIRLE-6

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-023	DOOR RELEASE: access control, buzzer	1	1	optional
ELGP-101	GPO: single, ceiling mounted	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	optional; for CCTV
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITSE-028	INTERCOM: audiovisual, wall mounted	1	1	optional, can be integral with CCTV system.
ITIN-011	OUTLET: data, single RJ45, ceiling mounted	1	1	
ITSE-038	READER: access control, general	1	1	optional; swipe card access