

Room Name Anaesthetic Preparation Room, 16m²
Room Number ANAE-16

Revision

1

Issue Date

02.07.2018

BRIEFING
Briefed Area

 16.00 m²
Hours of Operation

Available 24 Hours

Occupancy

1 patient; 1 parent; up to 3 staff

Acoustics

Acoustic privacy is required

Remarks
**Description /
Special Requirements**

The Anaesthetic Preparation Room is for holding patients on mobile beds or trolleys prior to operative procedures. Local, regional or general anaesthesia may be administered in this area. If serving an Operating Room with cardiac protected power, the Anaesthetic Preparation Room should also have cardiac protected power.

SERVICES
General Requirements

BODY PROTECTED

CARDIAC PROTECTED

Air

AIRCONDITIONING

AIRCONDITIONING: hepa filtered

AIRCONDITIONING: positive pressure

AIRCONDITIONING: negative pressure

EXHAUST: room exhaust

VENTILATION

Lighting

LIGHTING: colour corrected

LIGHTING: dimmable

LIGHTING: downlights

LIGHTING: downlights, dimmable

LIGHTING: fluorescent/LED, downlights

LIGHTING: fluorescent/LED, flush with ceiling, tamper proof

LIGHTING: fluorescent/LED, general

LIGHTING: indirect

Nurse Call

NURSE CALL SYSTEM

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-051	DOOR: 1600mm c/o, double leaf, observation panel, solid core/glass, paint	auto release, delayed action, magnetic lead flap to be installed over glass if laser is in use
DWGL-053	DOOR: 1600mm c/o, double leaf, sliding, observation panel, solid core/glass, paint	manual release, delayed action
DWPR-011	DOOR PROTECTION: protection plate, to full height	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

Room Name | Anaesthetic Preparation Room, 16m²
Room Number ANAE-16

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	
FQCW-004	BIN: waste, clinical, 120L	3	1	optional, dependent on waste management policy
FQCW-016	BIN: waste, general, 20L	3	1	
FIHR-063	BRACKET: for all-in-one computer, with keyboard shelf, wall mounted	2	1	
FIHR-019	BRACKET: for suction bottle	2	2	
FIJO-212	BULKHEAD: joinery	1	1	optional, install over joinery when used, plasterboard bulkhead is a suitable alternative
MMGE-014	CHAIR: anaesthetist	3	1	
ITCL-018	CLOCK: clock system slave, digital	1	1	mount flush with wall
ITNE-066	COMPUTER: all-in-one, wall mounted	3	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	2	optional
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-021	DISPENSER: mask	2	1	to entry
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	
MMGE-039	HANGER: IV, for ceiling track	1	1	
ITNE-067	KEYBOARD: keyboard and mouse only	3	1	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMOP-040	MACHINE: anaesthetic	3	0	space allowance only
FIJO-213	PANEL: joinery carcass end	1	2	
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	3	
FIHR-062	RACK: wire basket	2	4	
MMGE-088	SAFE: dangerous drugs, small	1	1	
MMGE-100	SUCTION BOTTLE	3	2	
HYTP-042	TAPWARE: sensor	1	1	
ITNE-052	TELEPHONE: handset, wall mount	1	1	
FIRT-020	TRACK: ceiling mounted, IV	1	1	
MMBE-044	TROLLEY: patient, transport	3	1	
MMGE-142	TROLLEY: sharps bin	3	2	

Engineering Services

Room Name | **Anaesthetic Preparation Room, 16m²**
Room Number ANAE-16

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-005	BUTTON: nurse call, orderly / porter	1	1	optional
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ITSE-025	DOOR RELEASE: access control, remote activation	1	1	
MEEX-008	EXHAUST: low level	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	3	
ELGP-123	GPO: emergency power, single, wall mounted	1	5	to bench, computer
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	
LIFX-003	LIGHT: illuminated sign, "Laser in Use"	1	1	
LIFX-002	LIGHT: illuminated sign, "X-Ray in Use"	1	1	wording on light to jurisdictional requirements
LIFX-016	LIGHT: pelmet light	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	2	
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	
MGAS-053	OUTLET: scavenge, on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	2	
ELPR-006	RCD: residual current device	1	2	
MMSP-026	SERVICES PANEL: wall mounted	1	1	recessed
ELBO-015	SWITCH: light, single	1	3	