

Room Name	Angiography Control/ Reporting Room		Room Number ANCRT
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	14.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 3 staff		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	Room adjacent to Angiography Procedure Room/s with direct visibility to the patient for remote control of equipment, and review and reporting of procedure images. The Control/ Reporting room may serve two procedure rooms. Additional Design Considerations: Radiation shielding as advised by Radiation Consultant. Cable ducts from Angiography Procedure Room and Computer/Equipment room may be required.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No	
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No	
	EXHAUST: room exhaust = No	VENTILATION = No	
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No	
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No	
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No	
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-003	DOOR PROTECTION: kickplate, to 300 AFFL, vinyl, prefinished	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-009	OBSERVATION: internal window, lead glass, clear	to procedure room
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-044	BENCH: special depth, open under	1	3	800/600D, at 900H, laminate finish
FQBS-019	CHAIR: office, ergonomic, high	3	3	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
MMMI-013	CONSOLE: control, examination control console, angiography single plane ceiling	1	1	Angiography control monitors
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	6	for books, manuals, over bench

Room Name | **Angiography Control/ Reporting Room**

Room Number **ANCRT**

AusHFG code	Description	Group	Qty	Comment
MMMI-356	DISPLAY SCREEN: dual screen, angiography	3	1	
FIHR-026	HOOK: coat	1	2	
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	3	over bench
WLPT-003	PARTITION: laminate	1	2	as required
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	1	under bench
ITNE-023	PRINTER: networked	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	2	on bench
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	9	
ELGP-106	GPO: single, special, for equipment	1	1	Angiography console equipment
ITSE-029	INTERCOM: audio, wall mount	1	1	with handsfree microphone to Angio room
LIFX-008	LIGHT: task light, built in	1	4	under O/H shelving
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	6	3 outlets under bench for telephone
ELBO-015	SWITCH: light, sing	1	2	

RETIRED