

Room Name	Anaesthetic Induction Room		Room Number ANIN
<b>Revision</b>	4		
<b>Issue Date</b>	20.03.17		
<b>BRIEFING</b>			
<b>Briefed Area</b>	15.00 m <sup>2</sup>		
<b>Hours of Operation</b>	Available 24 Hours		
<b>Occupancy</b>	1 patient; up to 3 staff		
<b>Acoustics</b>	Acoustic privacy is required		
<b>Remarks</b>			
<b>Description / Special Requirements</b>	The Anaesthetic Room is for holding patients on mobile beds or trolleys prior to operative procedures at times when the Operating Room is not available. Local, regional or general anaesthesia may be administered in this area. Depending on special circumstances an Anaesthetic Induction Room of 18 m2 is also acceptable.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
<b>Air</b>	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = Yes AIRCONDITIONING: negative pressure = No VENTILATION = No	
<b>Lighting</b>	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
<b>Nurse Call</b>	NURSE CALL SYSTEM = Yes		

# RETIRED

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-007	CORNICE: plasterboard, flush coved between wall and ceiling, paint	
DWGL-042	DOOR: 1500mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	sliding covers to obs panels
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-006	FLOOR FINISH: vinyl, seamless, coved, non slip, textured	under basin
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin, tiles also acceptable
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to Acrovyn

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	Refer to BWHS-A (similar)
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	open under part

**Room Name | Anaesthetic Induction Room**
**Room Number ANIN**

AusHFG code	Description	Group	Qty	Comment
FQSN-006	BIN: storage bins, for wall mounted panel	3	10	
FQCW-004	BIN: waste, clinical, 120L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	on bench
FIHR-001	BRACKET: arm, cable/hose support, wall mounted	3	1	optional
FIHR-011	BRACKET: for monitor	3	1	optional
FIHR-019	BRACKET: for suction bottle	2	2	on equipment rail
ITCL-016	CLOCK: clock system slave, analogue	1	1	
FIJO-102	CUPBOARD: drawer unit	1	1	under bench
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	
FIJO-148	CUPBOARD: wall mount, double door, glazed, adj shelves, lockable	1	3	overbench
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-021	DISPENSER: mask	3	1	to entry
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	
MMGE-036	FRIDGE: drugs, underbench	3	1	under bench, optional
LIFX-013	LIGHT: procedure, ceiling, 1500mm, sma	1	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMHA-008	MONITOR: patient, cardiac with vital signs	3	1	optional
FIHR-033	PANEL: for storage bins, wall mount	1	3	457mmx457mm, over bench
FIRT-012	RAIL: equipment	1	1	under services panel
MMGE-100	SUCTION BOTTLE	3	2	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	to bench
FQSM-016	TROLLEY	3	1	

RETIRED

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-005	BUTTON: nurse call, orderly / porter	1	1	optional
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-206	GPO: double, on services panel, RCD protected	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	3	
ELGP-123	GPO: emergency power, single, wall mounted	1	1	to monitor
ELGP-123	GPO: emergency power, single, wall mounted	1	4	to bench

**Room Name** | **Anaesthetic Induction Room**
**Room Number ANIN**

AusHFG code	Description	Group	Qty	Comment
ELGP-105	GPO: single, on services panel	1	2	
ELGP-106	GPO: single, special, for equipment	1	2	clock, procedure light
ELGP-109	GPO: single, wall mounted	1	3	to walls (1 for fridge)
LIFX-008	LIGHT: task light, built in	1	2	under O/H cupboards
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	
MGAS-053	OUTLET: scavenge, on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	2	
MMSP-026	SERVICES PANEL: wall mounted	2	1	recessed
ELBO-015	SWITCH: light, single	1	2	

# RETIRED