

Room Name	Anteroom	Room Number ANRM
<b>Revision</b>	4	
<b>Issue Date</b>	20.03.17	
<b>BRIEFING</b>		
<b>Briefed Area</b>	6.00 m <sup>2</sup>	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 - 2	
<b>Acoustics</b>		
<b>Remarks</b>		
<b>Description / Special Requirements</b>	Anteroom associated with an Isolation room for maintenance of air pressurisation and for staff and visitors to change and dispose of protective gear used on entering or exit; a staff handwashing basin will be located within the room; glazing is recommended for patient and staff visibility. Pressurisation - negative or positive depending on type of Isolation room Body Protected electrical area	
<b>SERVICES</b>		
<b>General Requirements</b>	BODY PROTECTED = Yes	CARDIAC PROTECTED = No
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = Yes
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
<b>Nurse Call</b>	NURSE CALL SYSTEM = No	

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-002	DOOR: 910mm c/o, single leaf, half glazed, solid core/glass, paint	From Corridor to Anteroom. Staff movement.
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to 'Acrovyn'
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to 'Acrovyn'
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	To basin; selected material to comply with Infection Control Guidelines
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	Under basin.
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	Refer to BHW-B (similar)
FQCW-016	BIN: waste, general, 20L	3	1	

**Room Name** | Anteroom

**Room Number ANRM**

AusHFG code	Description	Group	Qty	Comment
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-022	DISPENSER: moisturiser	2	1	to basin, optional. Depends on operational policy.
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
FIHR-026	HOOK: coat	1	4	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	Elbow action levers or handsfree optional.
MMGE-137	TROLLEY: PPE	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	2	