

Room Name	Angiography Sterile Store/ Set-up		Room Number ANSS
<b>Revision</b>	3		
<b>Issue Date</b>	20.03.17		
<b>BRIEFING</b>			
<b>Briefed Area</b>	10.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 - 2 intermittently		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	A room for the storage and preparation of radiological media, sterile stock, medications and where set-up for Angiography procedures is undertaken. Secured staff only access to the room may be required.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = No	CARDIAC PROTECTED = No	
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
<b>Nurse Call</b>	NURSE CALL SYSTEM = No		

# RETIRED

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	lockable
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	tiles also acceptable

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	Refer to BHWS-B (similar)
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	2	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	

**Room Name | Angiography Sterile Store/ Set-up**
**Room Number ANSS**

AusHFG code	Description	Group	Qty	Comment
FIJO-117	CUPBOARD: tall, double door, adj shelves, lockable	1	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	2	over bench
FIJO-147	CUPBOARD: wall mount, double door, glazed, adj shelves	1	1	
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	2	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MMGE-036	FRIDGE: drugs, underbench	3	1	optional
FIHR-033	PANEL: for storage bins, wall mount	1	2	above bench, optional
MMGE-088	SAFE: dangerous drugs, small	1	1	optional
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	optional, on bench

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-109	GPO: single, wall mounted			
ELGP-109	GPO: single, wall mounted	1	1	Refrigerator, under bench
LIFX-008	LIGHT: task light, built in	1	3	under O/H cupboards
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ELBO-015	SWITCH: light, single	1	2	

RETIRED