

**Room Name | Audiology Testing Room**
**Room Number AUDIO**
**Revision** 3  
**Issue Date** 20.03.17

**BRIEFING**

**Briefed Area** 14.00 m<sup>2</sup>  
**Hours of Operation** 8am to 6pm, daily  
**Occupancy** Up to 3  
**Acoustics** Acoustic privacy is required  
**Remarks**  
**Description / Special Requirements** Room with an internal sound proof booth to specifications, for audiology testing. Audiometric booth should be ventilated or connected to air-conditioning, power and data. Level access to the Audiometric Booth is recommended.

**SERVICES**

**General Requirements** BODY PROTECTED = Yes                      CARDIAC PROTECTED = No  
**Air** AIRCONDITIONING = Yes                      AIRCONDITIONING: hepa filtered = No  
          AIRCONDITIONING: positive pressure = No                      AIRCONDITIONING: negative pressure = No  
          EXHAUST: room exhaust = No                      VENTILATION = No  
**Lighting** LIGHTING: colour corrected = No                      LIGHTING: dimmable = No  
                  LIGHTING: downlights = No                      LIGHTING: downlights, dimmable = Yes  
                  LIGHTING: fluorescent, downlights = No                      LIGHTING: fluorescent, flush with ceiling, tamper proof = No  
                  LIGHTING: fluorescent, general = Yes                      LIGHTING: indirect = No  
**Nurse Call** NURSE CALL SYSTEM = No

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-003	DOOR PROTECTION: kickplate, to 300 AFFL, vinyl, prefinished	
FLCP-003	FLOOR FINISH: carpet, broadloom, 48 oz., 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
MMAH-005	BOOTH: audiometric	3	1	to specification
FQBS-012	CHAIR: child	3	1	as required
FQBS-014	CHAIR: client	3	3	
FQBS-018	CHAIR: office, ergonomic	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
MMAH-036	CONSOLE: control, audiometric booth	3	1	

**Room Name | Audiology Testing Room**
**Room Number AUDIO**

AusHFG code	Description	Group	Qty	Comment
FQDW-002	DESK: adj height, 1800W x 750D x 750H nom.	3	1	
FIHR-026	HOOK: coat	1	2	
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	1	under desk
FQTA-032	TABLE: rectangular, 850L x 550W, work height	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	on desk
FIBM-018	WHITEBOARD: fixed	2	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
FSDE-004	DETECTOR: smoke	1	1	
ELGP-208	GPO: double, wall mounted	1	4	2- desk; 2-booth
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-106	GPO: single, special, for equipment	1	1	audiometric booth
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	1 to booth, 1 outlet to desk for telephone
ELBO-015	SWITCH: light, single	1	3	