

Room Name | Bay - ATM, 2m2

Room Number BATM-2

Revision 3
Issue Date 20.03.17

BRIEFING
Briefed Area 2.00 m²
Hours of Operation 24 Hours
Occupancy N/A
Acoustics
Remarks
Description / Special Requirements

The ATM Bay will provide an area for an ATM machine which may require access to the rear of the ATM by staff or authorised personnel only. The ATM bay may be located in close proximity to a waiting area, retail precinct or within main entrance area that is not visible from outside. Provision of power and data to be according to ATM specifications.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = No

Air

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

Lighting

LIGHTING: colour corrected = No

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = Yes

LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	Acoustic tiles acceptable.
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = vinyl or other suitable slip resistant floor finish.
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Default = or to suit built fabric.
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	Align heights of corner guards with other corridor elements

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIHR-002	BRACKET: for CCTV camera, ceiling mounted	1	1	
ITSE-012	CAMERA: CCTV	1	1	optional: linked to Security
FQGE-034	MACHINE: ATM	3	1	to be provided by contracted supplier.

Engineering Services

Room Name | Bay - ATM, 2m2

Room Number BATM-2

AusHFG code	Description	Group	Qty	Comment
FSDE-004	DETECTOR: smoke	1	1	
FSPV-014	FIRE SUPPRESSION: sprinklers	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	
ELGP-109	GPO: single, wall mounted	1	1	ATM machine, concealed, as specified
ELGP-135	GPO: UPS, single, wall mounted	1	1	optional: CCTV camera
LIFX-030	LIGHT: downlight, recessed, compact fluorescent	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	ATM machine, concealed; number of data outlets as per ATM specifications.
ITIN-011	OUTLET: data, single RJ45, ceiling mounted	1	1	
MESU-011	SUPPLY AIR: grille	1	1	