

Room Name	Bay - Blanket/ Fluid Warmer	Room Number BBW
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	1.00 m ²	
Hours of Operation	24 Hours	
Occupancy		
Acoustics		
Remarks		
Description / Special Requirements	A Bay for a blanket or combined blanket / fluid warming cabinet. The bay should have close access to patient areas and operating rooms. Assess dimensions of cabinet to ensure space is adequate. When blanket warming is accommodated, ideally located near a Linen Bay.	
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	Acoustic tiles acceptable.
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	Align heights of corner guards with other corridor elements

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-010	CABINET: blanket/ fluid warming	3	1	Freestanding

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-123	GPO: emergency power, single, wall mounted	1	1	