

Room Name	Bay - Handwashing, Type A		Room Number BHWS-A
Revision	5		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	1.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1		
Acoustics			
Remarks			
Description / Special Requirements	A bay off or within a patient bedroom/treatment area, with handwashing facilities for staff to cleanse their hands before and after every patient contact. Type A refers to a Clinical Scrub basin (large) with non-touch taps. Bay height to be consistent with adjacent doorway height.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = Yes LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	acoustic tiles acceptable
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	significant change in colour to be avoided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	selection of material to comply with Part D Infection Prevention and Control AusHFG
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	align heights of corner guards with other corridor elements

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-009	BASIN: handwash, Type A, scrub	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	

Room Name | Bay - Handwashing, Type A

Room Number BHWS-A

AusHFG code	Description	Group	Qty	Comment
FIDI-031	DISPENSER: soap antiseptic	2	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	hands-free taps optional; tap placement should allow washing up to the elbow

Engineering Services

AusHFG code	Description	Group	Qty	Comment
LIFX-030	LIGHT: downlight, recessed, compact fluorescent	1	1	