

Room Name	Bay - Handwashing, Type B		Room Number BHWS-B
Revision	6		
Issue Date	18.01.2021		
BRIEFING			
Briefed Area	1.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1		
Acoustics			
Remarks			
Description / Special Requirements	The Bay - Handwashing, Type B provides handwashing facilities for staff use before and after every patient contact and visitor use as required. The basin is to be a medium, wall-mounted type, with hands-free taps that may be either wall-mounted or basin-mounted elbow operated taps. Warm and cold water are to be delivered by a common spout.		
SERVICES			
General Requirements	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	ceiling tiles are also acceptable, ceiling to be coordinated with adjacent area
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	floor finish of adjacent area must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin. significant change in colour to be avoided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	
WLPR-006	WALL PROTECTION: corner guards	if bay is recessed

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	

Room Name | Bay - Handwashing, Type B

Room Number BHWS-B

AusHFG code	Description	Group	Qty	Comment
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	
FIDI-031	DISPENSER: soap antiseptic	2	1	optional, dependent on service requirements
HYTP-037	TAPWARE: mixer, elbow levers	1	1	

Engineering Services