

Room Name | Bay - Handwashing, Type C

Room Number BHWS-C

Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 1.00 m²
Hours of Operation 24 Hours
Occupancy 1
Acoustics
Remarks
Description / Special Requirements Handwashing facilities for staff, patients and public amenity. Type C refers to a Small to Medium hand basin with a lever, or a flickmixer tap for general handwashing.

SERVICES
General Requirements BODY PROTECTED = No CARDIAC PROTECTED = No
Air AIRCONDITIONING = Yes AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = No VENTILATION = No
Lighting LIGHTING: colour corrected = No LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = Yes LIGHTING: indirect = No
Nurse Call NURSE CALL SYSTEM = No

RETIRED

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	acoustic tiles acceptable
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	significant change in colour to be avoided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	selection of material to comply with Part D Infection Prevention and Control AusHFG
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	align heights of corner guards with other corridor elements

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	

Room Name | Bay - Handwashing, Type C

Room Number BHWS-C

AusHFG code	Description	Group	Qty	Comment
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	basin mounted lever or single lever mixer tap

Engineering Services

RETIRED