

Room Name	Bay - Height/ Weight	Room Number BHW
<b>Revision</b>	4	
<b>Issue Date</b>	28.06.2021	
<b>BRIEFING</b>		
<b>Briefed Area</b>	2.00 m <sup>2</sup>	
<b>Hours of Operation</b>	Available 24 hours	
<b>Occupancy</b>	1 patient and 1 staff, intermittently	
<b>Acoustics</b>	Sound attenuation level medium, Acoustic privacy is required.	
<b>Remarks</b>		
<b>Description / Special Requirements</b>	<p>An open bay for measuring and recording the height and weight of patients. Standing scales and a stadiometer are typically provided. Chair scales may be used here or may be stored here to be used elsewhere in the department as required. The type of scales and provision for bariatric patients will be dependent on service requirements.</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> <li>The bay should deep enough to ensure that equipment does not impede adjacent corridor circulation. Design and location of bay should allow for intermittent use without significant disruption to circulation in adjacent corridor.</li> <li>Grab rails for patient stability may be provided and may be either integral to the scales or wall mounted.</li> </ul>	
<b>SERVICES</b>		
<b>Electrical</b>	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>HVAC</b>	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Security / Nurse Call</b>	NURSE CALL SYSTEM <input type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	coordinated with adjacent area
CLCN-009	CORNICE: wall trim fixing	coordinated with adjacent area
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	coordinated with adjacent area
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	coordinated with adjacent area
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-022	WALL FINISH: vinyl, to 900 AFFL	height dependent on type and height of mobile equipment, crash rails are also acceptable
WLPR-006	WALL PROTECTION: corner guards	coordinated with adjacent wall protection

**Fittings, Furniture and Equipment (FF&E) Items**

**Room Name | Bay - Height/ Weight**
**Room Number BHW**

AusHFG code	Description	Group	Qty	Comment
MMGE-089	SCALES: electronic, chair	3	1	optional, dependent on service requirements
MMGE-188	SCALES: electronic, standing, with stadiometer	3	1	bariatric capacity will be dependent on service requirements; stadiometer may be separate wall mounted or floor standing item; scales may include integral grab rails for support

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	optional, dependent on equipment requirements