

Room Name	Blood Store	Room Number BLST
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	2.00 m ²	
Hours of Operation	24 Hours	
Occupancy		
Acoustics		
Remarks		
Description / Special Requirements	The Blood Store is a bay for refrigerated storage of blood and blood products. The Bay will be located with ready access to Operating Rooms and patient treatment areas.	
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	Equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMLA-053	FRIDGE: blood products, single door	3	3	with temperature monitor

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-223	GPO: emergency power, double, wall mounted	1	2	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	2	for temperature monitor/alarms, optional