

Room Name | Bay - Mobile Equipment, 4m2

Room Number BMEQ-4

Revision 5
Issue Date 20.03.17

BRIEFING
Briefed Area 4.00 m²
Hours of Operation 24 Hours
Occupancy
Acoustics
Remarks
Description / Special Requirements

An open storage bay for one or more items of mobile equipment in frequent use which may include wheelchairs, mobile scales, commode chairs, patient lifting devices or other mobile equipment. Special Design Requirements: the Bay should be deep enough to ensure equipment stored does not impede corridor circulation; a depth range from 800mm to 1500mm is recommended, depending on equipment to be stored. If imaging equipment is to be stored add 2m2 to bay. Electrical equipment that requires recharging may be stored in this space whilst recharging, therefore provision of appropriately located power outlets will be required.

SERVICES
General Requirements

BODY PROTECTED = No CARDIAC PROTECTED = No

Air

 AIRCONDITIONING = Yes AIRCONDITIONING: hepa filtered = No
 AIRCONDITIONING: positive pressure = No AIRCONDITIONING: negative pressure = No
 EXHAUST: room exhaust = No VENTILATION = No

Lighting

 LIGHTING: colour corrected = No LIGHTING: dimmable = No
 LIGHTING: downlights = No LIGHTING: downlights, dimmable = No
 LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 LIGHTING: fluorescent, general = Yes LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = No

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = vinyl: or carpet also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Feather edge vinyl skirting if carpeted
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-010	WALL PROTECTION: corner guards, to 900 AFFL	
WLPR-020	WALL PROTECTION: crash rail, at 350 AFFL	
WLPR-021	WALL PROTECTION: crash rail, at 900 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIHR-030	HOOK: equipment, on mounting plate	1	1	
MMBE-042	SLIDE: patient	3	1	

Engineering Services

Room Name | Bay - Mobile Equipment, 4m2

Room Number BMEQ-4

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	For recharging of electrical equipment