

**Room Name** | Bay - Mobile Equipment, 6m2

**Room Number** BMEQ-6

**Revision** 5  
**Issue Date** 20.03.17

**BRIEFING**
**Briefed Area** 6.00 m<sup>2</sup>  
**Hours of Operation** 24 Hours  
**Occupancy**  
**Acoustics**  
**Remarks**
**Description / Special Requirements**

An open storage bay for one or more items of mobile equipment in frequent use which may include imaging equipment, wheelchairs, mobile scales, commode chairs, patient lifting devices or other mobile equipment. Special Design Requirements: The Bay should be deep enough to ensure equipment stored does not impede corridor circulation; a depth range from 800mm to 1500mm is recommended, depending on equipment to be stored. Electrical equipment that requires recharging may be stored in this space whilst recharging, therefore provision of appropriately located power outlets will be required.

**SERVICES**
**General Requirements**

BODY PROTECTED = No                      CARDIAC PROTECTED = No

**Air**

 AIRCONDITIONING = Yes                      AIRCONDITIONING: hepa filtered = No  
 AIRCONDITIONING: positive pressure = No                      AIRCONDITIONING: negative pressure = No  
 EXHAUST: room exhaust = No                      VENTILATION = No

**Lighting**

 LIGHTING: colour corrected = No                      LIGHTING: dimmable = No  
 LIGHTING: downlights = No                      LIGHTING: downlights, dimmable = No  
 LIGHTING: fluorescent, downlights = No                      LIGHTING: fluorescent, flush with ceiling, tamper proof = No  
 LIGHTING: fluorescent, general = Yes                      LIGHTING: indirect = No

**Nurse Call**

NURSE CALL SYSTEM = No

**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default = vinyl: or carpet also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	feather edge vinyl if carpeted
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	Equal to 'Acrovyn'
WLPR-018	WALL PROTECTION: crash rail, at 350 AFFL, prefinished PVC	Optional; Equal to 'Acrovyn'
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to Acrovyn

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMMI-330	DEVICE: imaging, X-Ray machine, mobile	3	1	parking area
MMGE-119	TROLLEY: equipment	3	1	as required
MMBE-045	WHEELCHAIR	3	2	as required

Room Name | Bay - Mobile Equipment, 6m2

Room Number BMEQ-6

## Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	For recharging of electrical equipment