

Room Name	Bay - Mobile Equipment	Room Number BMEQ
<b>Revision</b>	6	
<b>Issue Date</b>	28.06.2021	
<b>BRIEFING</b>		
<b>Briefed Area</b>	4.00 m <sup>2</sup>	
<b>Hours of Operation</b>	Available 24 hours	
<b>Occupancy</b>		
<b>Acoustics</b>		
<b>Remarks</b>		
<b>Description / Special Requirements</b>	<p>An open bay for storage and recharging frequently used mobile equipment. Equipment may include wheelchairs, mobile scales, commode chairs, patient lifting devices or observation/diagnostic equipment.</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> <li>The bay should deep enough to ensure that equipment does not impede adjacent corridor circulation; a depth range from 800mm to 1500mm is recommended. Consider the manoeuvrability of equipment to be stored as some items may have large turning circles and will need to be parked perpendicular, requiring a deeper bay. Power outlets may be located on the sides of deeper bays to be accessible when equipment is parked.</li> <li>If portable imaging equipment is to be stored additional area may be required. Data outlets may be required depending on equipment.</li> <li>Equipment may be recharged while stored in this space; provision of appropriately located power outlets is required.</li> <li>Items may be hung in this bay, e.g. a patient slide, and appropriate in-wall supports are required for mounting hooks.</li> </ul>	
<b>SERVICES</b>		
<b>Electrical</b>	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>HVAC</b>	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Security / Nurse Call</b>	NURSE CALL SYSTEM <input type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	coordinated with adjacent area
CLCN-009	CORNICE: wall trim fixing	coordinated with adjacent area
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	coordinated with adjacent area
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	coordinated with adjacent area
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	height dependent on type and height of mobile equipment, crash rails are also acceptable

**Room Name | Bay - Mobile Equipment**
**Room Number BMEQ**

AusHFG code	Description	Comment
WLPR-006	WALL PROTECTION: corner guards	coordinated with adjacent wall protection

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
FIHR-030	HOOK: equipment, on mounting plate	1	1	optional
MMBE-042	SLIDE: patient	3	1	optional

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	type, quantity and configuration of outlets to be determined based on equipment requirements