

Room Name	Bay - Pathology	Room Number BPATH
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	1.00 m ²	
Hours of Operation	24 Hours	
Occupancy	1 - 2 staff	
Acoustics		
Remarks		
Description / Special Requirements	A space for the preparing and testing a range of specimens. This space has been based on four (4) benchtop POCT devices. This level of provision may be more common in critical care areas. The space is dependent on the number of devices used in each clinical situation. In a multi-device bay, 300mm gap between each device is recommended. Design to consider height clearances if above bench joinery is installed. This space to be colocated with a pneumatic tube bay and in an area that is supervised by staff. Assumes that staff will access a hand hygiene bay nearby. The workspace will suit a staff member who is standing. Design consideration as to the weight of some POCT devices.	
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling.
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	Acoustic tiles acceptable
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	Align heights of corner guards with other corridor elements

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-069	BENCH TOP: 750D, joinery under, laminate finish	1	1	With optional inset sink. Length to suit layout, refer RLS or project specific requirements.
FQSN-006	BIN: storage bins, for wall mounted panel	3	2	Number to suit.
FQCW-005	BIN: waste, clinical, 20L	3	1	

Room Name | Bay - Pathology
Room Number BPATH

AusHFG code	Description	Group	Qty	Comment
FQCW-044	BIN: waste, sharps, wall mounted	3	1	Optional.
FIHR-016	BRACKET: for sharps bin	2	1	Optional.
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	Number to suit layout, refer RLS or project specific requirements.
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	4	Over bench. Number to suit layout, refer RLS or project specific requirements.
MMLA-049	DEVICE: point of care	3	1	Number to be project specific.
FIDI-001	DISPENSER: alcohol based hand rub	2	1	May not be required if Hand Hygiene Bay colocated.
MMGE-036	FRIDGE: drugs, underbench	3	1	Local temperature monitoring. Optional, depends on frequency of collection.
FIHR-033	PANEL: for storage bins, wall mount	1	1	Over bench. Number to suit layout.
FQGE-056	PRINTER: desktop, labels	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	Bench or wall mounted, optional.

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	4	Number depends on project specific requirements.
ELGP-223	GPO: emergency power, double, wall mounted	1	1	
LIFX-008	LIGHT: task light, built in	1	2	under O/H cupboards
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	4	Number depends on project specific requirements.