

Room Name	Bay - Wheelchair Park		Room Number BWC
Revision	5		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	4.00 m ²		
Hours of Operation	24 Hours		
Occupancy			
Acoustics			
Remarks			
Description / Special Requirements	An open storage bay for wheelchairs, located in close proximity to the main entrance. Special Design Requirements: the Bay should be deep enough to ensure equipment stored does not impede corridor circulation; minimum depth 1200mm.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	consistent with adjacent area
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	consistent with adjacent area
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	consistent with adjacent area
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	consistent with adjacent area
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	Equal to 'Acrovyn'
WLPR-018	WALL PROTECTION: crash rail, at 350 AFFL, prefinished PVC	Equal to 'Acrovyn'
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMBE-045	WHEELCHAIR	3	3	as required

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	1	