

Room Name	Bay - Water Fountain		Room Number BWTR
Revision	4		
Issue Date	24.06.2022		
BRIEFING			
Briefed Area	1.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	1 intermittently		
Acoustics			
Remarks			
Description / Special Requirements	<p>An area, typically associated with a main entry lobby or waiting area, for a drinking water dispenser. The water dispenser may be in a recessed bay or in an open area and should be located to ensure adjacent circulation paths are not impeded with intermittent use.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> A water dispenser with a spout to fill disposable cups or refill drink bottles is recommended. Hand hygiene facilities, such as alcohol-based hand rub, should be provided nearby in line with local infection control policies. 		
SERVICES			
Electrical	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	coordinated with adjacent area
CLCN-009	CORNICE: wall trim fixing	coordinated with adjacent area
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	floor finish of adjacent area must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under water dispenser. significant change in colour to be avoided.
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	

Room Name | **Bay - Water Fountain**
Room Number BWTR

AusHFG code	Description	Group	Qty	Comment
HYGE-011	CHILLED WATER UNIT: fixed	1	1	
FQCA-014	DISPENSER: cup	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-111	GPO: single, wall mounted, RCD protected	1	1	optional, for refrigerated units only