

Room Name | **Change Room - Patient (Male/Female), 12m2** | **Room Number** **CHPT-12**
Revision | 3
Issue Date | 20.03.17

BRIEFING
Briefed Area | 12.00 m²
Hours of Operation | 24 Hours
Occupancy | Up to 3
Acoustics | Sound attenuation level - medium; acoustic privacy required.
Remarks
Description / Special Requirements | The Patient Change areas are provided for patients to change into gowns, to store their street clothing and to perform personal ablutions. Change Rooms should be divided into Male and Female areas on a proportional basis and will include Change Cubicle, Toilet, handbasin and lockers for secure storage of personal property.

SERVICES
General Requirements | BODY PROTECTED = Yes | CARDIAC PROTECTED = No
Air | AIRCONDITIONING = Yes | AIRCONDITIONING: hepa filtered = No
 | AIRCONDITIONING: positive pressure = No | AIRCONDITIONING: negative pressure = No
 | EXHAUST: room exhaust = Yes | VENTILATION = No
Lighting | LIGHTING: colour corrected = No | LIGHTING: dimmable = No
 | LIGHTING: downlights = No | LIGHTING: downlights, dimmable = No
 | LIGHTING: fluorescent, downlights = No | LIGHTING: fluorescent, flush with ceiling, tamper proof = No
 | LIGHTING: fluorescent, general = Yes | LIGHTING: indirect = No
Nurse Call | NURSE CALL SYSTEM = Yes

Room Fabrics

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	optional, 910mm outward opening, privacy latch, with emergency release
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	To be decided at project level.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default= vinyl, carpet also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Feather edged vinyl if carpeted
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	To basin. Selection of material to comply with Part D Infection Prevention and Control AusHFG.

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	With vanity, or ensuite basin with integral shelf for patient belongings.

Room Name | **Change Room - Patient (Male/Female), 12m2**
Room Number **CHPT-12**

AusHFG code	Description	Group	Qty	Comment
FIGE-003	BENCH SEAT: fixed, indoor	1	1	To change cubicle. Or chair, consider weight capacity.
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-037	BIN: waste, sanitary	3	1	To Female Change Rooms. Optional, depends on Waste Management Policy.
FQBS-030	CHAIR: visitor, patient	3	1	
FQGE-005	CLOCK: analogue, battery operated	3	1	Optional
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	
FIDI-036	DISPENSER: toilet paper	1	1	
FIRT-006	GRAB RAIL: WC	1	2	Ambulant provision.
FIHR-026	HOOK: coat	1	2	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FQSN-048	LOCKER: 2 tier (half size)	3	4	16 half lockers or quarter lockers.
FQSN-050	LOCKER: 4 tier (quarter size)	3	2	
FIBM-006	MIRROR: fixed, glass	1	1	
WLPT-001	PARTITION: change cubicle	1	1	
WLPT-005	PARTITION: toilet	1	1	
FIJO-191	SHELF: above basin	1	1	Or integrated with basin.
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	to basin
HYWC-006	TOILET SUITE: patient	1	1	
MMGE-122	TROLLEY: gowns	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	2	+ indicator button & light. WC and change cubicle.
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	1	Optional.
ELBO-015	SWITCH: light, single	1	1	