

Room Name	Change Cubicle - Patient, 2m2		Room Number	CHPT
Revision	5			
Issue Date	20.03.17			
BRIEFING				
Briefed Area	2.00 m ²			
Hours of Operation	24 Hours			
Occupancy	1 patient			
Acoustics				
Remarks				
Description / Special Requirements	The change cubicle is provided for ambulant patients to undress from street clothes into a hospital gown, as appropriate, prior to examination or treatment. Following examination or treatment, the patient will re-dress in street clothes. The Change Cubicle should provide facilities for hanging clothes and a bench for the patient to sit on whilst changing. Special Requirements: Where two-way access is provided the corridor side door should be lockable from the inside to provide security to patient belongings. Where rooms serve a Day Surgery service locker space may be needed.			
SERVICES				
General Requirements	BODY PROTECTED = No		CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No		AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes		LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes			

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	Optional. Curtain across doorway also acceptable.
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	To be decided at project level.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Default= vinyl, carpet also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Feather edge vinyl if carpeted
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIGE-003	BENCH SEAT: fixed, indoor	1	1	Optional in lieu of chair.
FQBS-030	CHAIR: visitor, patient	3	1	optional in lieu of bench; consider weight capacity of chair.

Room Name | **Change Cubicle - Patient, 2m2**
Room Number **CHPT**

AusHFG code	Description	Group	Qty	Comment
FQGE-010	CURTAIN: privacy screen	3	1	
FIHR-026	HOOK: coat	1	2	at 1200 AFFL for wheelchair users
FIBM-005	MIRROR: fixed, glass, 1200H nom.	1	1	for patient changing
FIRT-031	TRACK: curtain, privacy	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light, outside cubicle entry, optional - may be shared between a group of rooms
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELBO-015	SWITCH: light, single	1	1	