

**Room Name** | Clean-Up Room - Shared, 10m2

**Room Number** CLUP-10

**Revision** 1  
**Issue Date** 02.07.2018

**BRIEFING**
**Briefed Area** 10.00 m<sup>2</sup>  
**Hours of Operation** 24 Hours  
**Occupancy** 1 - 2 staff  
**Acoustics**  
**Remarks**
**Description / Special Requirements**

The Clean-Up Room - Shared is used for rinsing and cleaning of medical equipment used in the Operating Rooms or Procedure Rooms. The shared Clean-up Room should be located between or close to the two Operating Rooms or Procedure rooms it serves. Backflow prevention required on all hydraulic fixtures.

**SERVICES**
**General Requirements**

 BODY PROTECTED  CARDIAC PROTECTED 
**Air**

 AIRCONDITIONING  AIRCONDITIONING: hepa filtered   
 AIRCONDITIONING: positive pressure  AIRCONDITIONING: negative pressure   
 EXHAUST: room exhaust  VENTILATION 
**Lighting**

 LIGHTING: colour corrected  LIGHTING: dimmable   
 LIGHTING: downlights  LIGHTING: downlights, dimmable   
 LIGHTING: fluorescent/LED, downlights  LIGHTING: fluorescent/LED, flush with ceiling, tamper proof   
 LIGHTING: fluorescent/LED, general  LIGHTING: indirect 
**Nurse Call**

 NURSE CALL SYSTEM 
**Room Fabrics**

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGE-016	DOOR: frame only	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	min. R11 rating
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-019	WALL FINISH: vinyl, full height	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	
FIJO-100	BENCH LEGS: stainless steel, for bench top	1	1	
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-012	BIN: waste, cytotoxic, 20L	3	1	optional
FQCW-016	BIN: waste, general, 20L	3	1	

**Room Name | Clean-Up Room - Shared, 10m2**
**Room Number CLUP-10**

AusHFG code	Description	Group	Qty	Comment
FQCW-017	BIN: waste, general, 240L	3	1	
FIDI-010	DISPENSER: detergent/chemical mixer	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MMOP-020	DOCKING STATION: surgical waste management system	2	1	optional, direct connect waste outlet to sewer system; docking station may be required only in a selection of clean up rooms across the unit (ie approx 1 per 4 ORs)
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FQCW-058	MOP	3	1	
FIHR-069	RACK: bottle	1	1	
FIHR-040	RACK: broom/mop	1	1	
FIJO-196	SHELF: stainless steel, overbench, wall mount	1	1	over sink bench
FIJO-197	SHELF: stainless steel, underbench	1	1	under sink bench
HYBA-052	SINK: single, 450 x 350 x 250D	1	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	2	one to sink, one to basin
HYDR-008	TRAP: plaster	1	1	optional
MMIC-121	TROLLEY: instruments transfer	3	1	temporarily located within room
MMGE-142	TROLLEY: sharps bin	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
HYDR-012	DRAIN: wall drain	1	1	optional, for surgical waste management system; floor drain connection in lieu of wall connection is also acceptable if allowed for in product specifications
ELGP-123	GPO: emergency power, single, wall mounted	1	1	optional, for surgical waste management system
HYTP-008	OUTLET: cold water	1	1	optional, for surgical waste management system
HYTP-008	OUTLET: cold water	1	1	for detergent dispenser
ELBO-015	SWITCH: light, single	1	1	