

Room Name | Clean-Up Room, 7m2

Room Number CLUP-7

Revision 5
Issue Date 13.05.2020

BRIEFING

Briefed Area 7.00 m²
Hours of Operation 24 Hours
Occupancy 1 - 2
Acoustics
Remarks
Description / Special Requirements The Clean-Up Room is used for holding of used trolleys and articles from an Operating Room, Procedure Room or Catheter Laboratory. Items may be sorted, rinsed or disposed of and despatched to waste holding/sterilising areas as appropriate.

SERVICES

General Requirements	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>		

Room Fabrics

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-005	WALL FINISH: paint, scrub resistant	
WLWA-021	WALL FINISH: vinyl, to 1800 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	elbow action levers
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	with wet edge
FIJO-100	BENCH LEGS: stainless steel, for bench top	1	1	
FQCW-008	BIN: waste, clinical, 50L	3	1	

Room Name | Clean-Up Room, 7m2

Room Number CLUP-7

AusHFG code	Description	Group	Qty	Comment
FQCW-060	BIN: waste, cytotoxic, 50L	3	1	optional
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-029	BIN: waste, recycling, paper, 240L	3	1	optional
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
MMIC-122	DISINFECTOR: ultrasound probes	3	1	optional
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FIJO-196	SHELF: stainless steel, overbench, wall mount	1	1	
FIJO-197	SHELF: stainless steel, underbench	1	1	
HYBA-052	SINK: single, 450 x 350 x 250D	1	1	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	1	1 to sink, 1 to basin
HYTP-038	TAPWARE: mixer, elbow levers, long	1	1	
FQSM-016	TROLLEY	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	1	