

Room Name | Clean-Up Room (Pathology), 12m2

Room Number CLUP-P

Revision 3
Issue Date 20.03.17

BRIEFING
Briefed Area 12.00 m²
Hours of Operation 24 Hours
Occupancy 1 - 2
Acoustics
Remarks
Description / Special Requirements The Clean-up Room is used for rinsing and cleaning of equipment and utensils used in the Pathology Unit, and disposal of waste.

SERVICES

General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

Room Fabrics

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-060	BENCH TOP: 600D, joinery under, stainless steel lipped	1	3	wet edge
FQCW-006	BIN: waste, clinical, 240L	3	2	
FQCW-016	BIN: waste, general, 20L	3	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	4	under SS bench

Room Name | Clean-Up Room (Pathology), 12m2
Room Number CLUP-P

AusHFG code	Description	Group	Qty	Comment
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	1	over part SS bench
FIJO-156	CUPBOARD: wall mount, single door, adj shelves	1	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	
HYTP-006	HOSE: spray, pressure control	1	1	to flushing rim sink, with flush button
FIJO-196	SHELF: stainless steel, overbench, wall mount	1	1	over sink bench
HYBA-043	SINK: double	1	1	
HYBA-046	SINK: flushing rim	1	1	in bench
HYTP-037	TAPWARE: mixer, elbow levers	1	2	1 to sink, 1 to basin
MMIC-097	WASHER SANITISER: utensil washer	1	1	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
HYDR-006	DRAIN: tundish	1	1	
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-106	GPO: single, special, for equipment	1	1	utensil washer, optional
ELPR-003	ISOLATOR: electrical, 1ph+n	1	1	
LIFX-008	LIGHT: task light, built in	1	1	
HYTP-008	OUTLET: cold water	1	1	for ioniser
HYTP-008	OUTLET: cold water	1	1	
HYTP-013	OUTLET: hot water	1	1	
MGAS-023	OUTLET: medical air (MA), wall mounted	1	1	near sinks for tube cleaning
ELBO-015	SWITCH: light, single	1	1	