

Room Name	Consult Room - ENT/ Ophthalmology		Room Number	CONS-ENT-OP
<b>Revision</b>	6			
<b>Issue Date</b>	29.05.2019			
<b>BRIEFING</b>				
<b>Briefed Area</b>	16.00 m <sup>2</sup>			
<b>Hours of Operation</b>	24 Hours			
<b>Occupancy</b>	1 patient; 1-2 staff, 1-2 visitors			
<b>Acoustics</b>	Sound attenuation level high, acoustic privacy is essential.			
<b>Remarks</b>				
<b>Description / Special Requirements</b>	The Consult Room ENT/ Ophthalmology will provide for private consultation and examination of patients for ENT/ Ophthalmology using specialised equipment. The Consult room may also be used for general consultations. A second egress door may be required for staff safety and security and/or staff access, subject to jurisdictional policy. Ready access to a fridge will be required for retrieval of eye medication. If eye testing is provided via a visual acuity chart and mirror, a distance of 3m is required between the eye chart and mirror for effective eye testing.			
<b>SERVICES</b>				
<b>General Requirements</b>	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
<b>Air</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable	<input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
<b>Nurse Call</b>	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>		

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-007	DOOR: 910mm c/o, single leaf, observation panel, solid core/safety glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to hand wash basin 2100mm high

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	

**Room Name | Consult Room - ENT/ Ophthalmology**
**Room Number CONS-ENT-OP**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-010	BENCH: 450D, open under	1	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to hand basin
FQCW-044	BIN: waste, sharps, wall mounted	3	1	wall mounted
MMGE-171	BOTTLE: eyewash, portable	3	1	
FIHR-011	BRACKET: for monitor, wall mounted	2	1	optional
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
ITCL-034	CAMERA: telemedicine	3	1	optional
FQBS-018	CHAIR: office, ergonomic	3	2	
MMGE-174	CHAIR: patient, ENT, electric	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	2	consider weight capacity of chair
ITNE-009	COMPUTER: hi performance, for clinical / PACS use	3	1	
FQGE-010	CURTAIN: privacy screen	3	1	
MMAH-013	DEVICE: eye examination, slit lamp	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin
FIDI-030	DISPENSER: soap	2	1	to hand basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to hand basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMHA-005	MONITOR: patient, cardiac	3	1	optional
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	1	
MMGE-173	PROJECTOR: visual acuity testing, surface mounted	3	1	project on wall, automated chart sizing
FQBS-051	STOOL: mobile, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	to desk
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
MMGE-113	TROLLEY: dressing	3	1	
FQDW-028	WORKSTATION: straight, adj height, 1200W x 750D x 750H nom.	3	1	

**Engineering Services**

**Room Name** | **Consult Room - ENT/ Ophthalmology**
**Room Number CONS-ENT-OP**

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	optional
ITCL-004	BUTTON: nurse call, emergency	1	2	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	2	+ indicator button & light
ELGP-223	GPO: emergency power, double, wall mounted	1	2	
ELGP-223.1	GPO: emergency power, double, wall mounted (V)	1	1	
ELGP-125	GPO: emergency power, single, ceiling mounted	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	4	
ELGP-123	GPO: emergency power, single, wall mounted	1	3	optional, to cardiac monitor
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	outlet for telephone, PC, telemedicine camera, slit lamp
ITIN-011	OUTLET: data, single RJ45, ceiling mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	optional, to cardiac monitor
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	optional, for paediatric use
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-053	OUTLET: scavenge, on services panel	1	1	optional, for paediatric use
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	1	
MMSP-026	SERVICES PANEL: wall mounted	1	2	
ELBO-012	SWITCH: light, dimmer	1	1	