

Room Name	Consult Room - ENT/ Ophthalmology		Room Number	CONS-ENT-OP
Revision	6			
Issue Date	29.05.2019			
BRIEFING				
Briefed Area	16.00 m ²	The use of nitrous oxide in operating theatres, procedural suites and emergency departments is declining due to a range of clinical and environmental concerns. It is, however, still commonly used in maternity and paediatric services. With the exception of maternity and paediatric services, reticulated nitrous oxide and associated scavenge outlets are to be considered optional. Where found to be clinically necessary, provision of nitrous oxide via piped outlets or via cylinder is to be determined at a project level, based on an assessment of expected clinical needs, security of gas sources, operational considerations such as monitoring and measurement of usage, and management of leakage.		
Hours of Operation	24 Hours			
Occupancy	1 patient; 1-2 staff, 1-2 visitors			
Acoustics	Sound attenuation level high, acoustic privacy is essential.			
Remarks				
Description / Special Requirements	The Consult Room ENT/ Ophthalmology will provide for private consultation and examination of patients for ENT/ Ophthalmology using specialised equipment. The Consult room may also be used for general consultations. A second egress door may be required for staff safety and security and/or staff access, subject to jurisdictional policy. Ready access to a fridge will be required for retrieval of eye medication. If eye testing is provided via a visual acuity chart and mirror, a distance of 3m is required between the eye chart and mirror for effective eye testing.			
SERVICES				
General Requirements	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
Air	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable	<input checked="" type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-007	DOOR: 910mm c/o, single leaf, observation panel, solid core/safety glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFLL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to hand wash basin 2100mm high

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	

Room Name | **Consult Room - ENT/ Ophthalmology**
Room Number CONS-ENT-OP

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-010	BENCH: 450D, open under	1	1	
FQCW-005	BIN: waste, clinical, 20L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to hand basin
FQCW-044	BIN: waste, sharps, wall mounted	3	1	wall mounted
MMGE-171	BOTTLE: eyewash, portable	3	1	
FIHR-011	BRACKET: for monitor, wall mounted	2	1	optional
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	
ITCL-034	CAMERA: telemedicine	3	1	optional
FQBS-018	CHAIR: office, ergonomic	3	2	
MMGE-174	CHAIR: patient, ENT, electric	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	2	consider weight capacity of chair
ITNE-009	COMPUTER: hi performance, for clinical / PACS use	3	1	
FQGE-010	CURTAIN: privacy screen	3	1	
MMAH-013	DEVICE: eye examination, slit lamp	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	2	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin
FIDI-030	DISPENSER: soap	2	1	to hand basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to hand basin
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-026	HOOK: coat	1	2	optional
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMHA-005	MONITOR: patient, cardiac	3	1	optional
FQSM-003	PEDESTAL: mobile, wire basket unit, 840H	3	1	
MMGE-173	PROJECTOR: visual acuity testing, surface mounted	3	1	project on wall, automated chart sizing
FQBS-051	STOOL: mobile, adj height	3	1	
MMGE-100	SUCTION BOTTLE	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	to desk
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	
MMGE-113	TROLLEY: dressing	3	1	
FQDW-028	WORKSTATION: straight, adj height, 1200W x 750D x 750H nom.	3	1	

Engineering Services

Room Name | **Consult Room - ENT/ Ophthalmology**
Room Number CONS-ENT-OP

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	optional
ITCL-004	BUTTON: nurse call, emergency	1	2	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	2	+ indicator button & light
ELGP-223	GPO: emergency power, double, wall mounted	1	2	
ELGP-223.1	GPO: emergency power, double, wall mounted (V)	1	1	
ELGP-125	GPO: emergency power, single, ceiling mounted	1	1	
ELGP-122	GPO: emergency power, single, on services panel	1	4	
ELGP-123	GPO: emergency power, single, wall mounted	1	3	optional, to cardiac monitor
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	outlet for telephone, PC, telemedicine camera, slit lamp
ITIN-011	OUTLET: data, single RJ45, ceiling mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	optional, to cardiac monitor
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	1	1	optional, for paediatric use
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-053	OUTLET: scavenge, on services panel	1	1	optional, for paediatric use
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	1	
MMSP-026	SERVICES PANEL: wall mounted	1	2	
ELBO-012	SWITCH: light, dimmer	1	1	